

Day	pH	Alk	Phos	Other	Y/N
1	7.86				Y
2	7.75				Y
3	7.91				Y
4	Off				
5	7.99	24			Y
6	Off				
7	7.79				Y
8	Off				
9	7.78				Y
10	Off				
11	7.88				Y
12	Off				
13	8.03	26			Y
14	Off				
15	8.07				Y
16	Off				
17	7.75				Y
18	Off	24			
19	8.18				Y
20	Off				
21	7.81				Y
22	Off				
23	8.08				Y
24	Off	25			
25	7.86				Y
26	Off				
27	7.78				Y
28	Off				
29					
30					
31					
Total N's					0

<<Have minimums been met for this day?

### ENTRY POINT

PWS ID: 41 0 0 3 1 7

**System Name:** City of Gates

**Entry Point:** A

**Sample Period:** February 2026  
*Month/Year*

**Number of excursions\* during this month: 0**  
*(Count the number of days when any WQP was less than the minimum required)*

**Total excursions during the previous 5 months: 0**  
*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative )*

*For OHA use only*

#### Minimum Water Quality Parameters as set by

pH 7.3

Alk 19.0 *(Alkalinity)*

PO4  *(Orthophosphate)*

Other  *(\_\_\_\_\_)*

**Print Name:** Gregory R Benthin

**Signature:** *Gregory R Benthin*

**Date:** March 5, 2026

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's**