

Lead & Copper Rule Corrosion Control

ID #	Sample Location	pH	Alk	PO4	other	Y/N
1						
2						
3						
4						
5						
6						
7	101 Sorbin Ave W	7.69	21			Y
8						
9						
10						
11						
12						
13						
14						
15						
16						
17						
18						
19						
20						
21	101 Sorbin Ave W	7.81	20			Y
22						
23						
24						
25						
26						
(N = No = Excursion) Total N's						0

<Has sample met the minimums?

DISTRIBUTION

PWS ID: 41 - 00317

System Name: City of Gates

Sample Period: November 2025
Month/Year

Sample Frequency: _____

Distribution Samples required: _____

Number of excursions during this Sample Period = 0

(Number of locations when any WQP was less than the minimum.)

Note: Entry Point and Distribution Excursions are cumulative. Add Entry Point and Distribution Excursions to get total for sample period.

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.5

Alk 19.0 (Alkalinity)

PO4 _____ (Orthophosphate)

Other _____ (_____)

Print Name: Gregory R Benthin

Signature: Gregory R Benthin

Date: 1/5/2026

Send to Drinking Water Program within 10 days after end of sampling period:

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>