

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.5	68			Y
2	7.4	64			Y
3	7.5	68			Y
4	7.5	64			Y
5	7.7	64			Y
6	7.9	60			Y
7	8.3	68			Y
8	8.1	64			Y
9	8.3	64			Y
10	8.2	60			Y
11	8.0	68			Y
12	8.3	68			Y
13	8.0	68			Y
14	7.9	64			Y
15	8.2	60			Y
16	8.0	64			Y
17	8.1	64			Y
18	7.9	68			Y
19	7.6	64			Y
20	7.6	64			Y
21	7.7	60			Y
22	7.5	64			Y
23	7.5	60			Y
24	7.4	68			Y
25	7.7	67			Y
26	7.5	72			Y
27	7.6	64			Y
28	7.7	66			Y
29	7.8	68			Y
30	8.0	68			Y
(No = N = Excursion) Total N's					0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

0	0	3	2	3
---	---	---	---	---

System Name: City of Glendale

Entry Point: EP-A

Sample Period: June 2021 Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

--

Alk

--

(Alkalinity)

PO4

--

(Orthophosphate)

Other

--

(_____)

Print Name: Michael Bollweg

Signature: Michael Bollweg

Date: 7.9.21

Send to DWP within 10 days after end of sampling period