



Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.9	60			Y
2	8.2	60			Y
3	7.9	60			Y
4	8.0	64			Y
5	8.0	68			Y
6	7.9	68			Y
7	7.8	64			Y
8	7.6	64			Y
9	7.7	64			Y
10	7.8	64			Y
11	7.6	60			Y
12	7.7	64			Y
13	7.8	68			Y
14	7.8	68			Y
15	7.7	64			Y
16	7.8	64			Y
17	7.6	64			Y
18	7.6	64			Y
19	7.9	60			Y
20	7.8	64			Y
21	8.0	68			Y
22	7.6	60			Y
23	7.7	64			Y
24	7.8	60			Y
25	7.8	68			Y
26	7.7	64			Y
27	8.0	68			Y
28	7.8	68			Y

<<Have minimums been met for this day?

County: Douglas Agency: REGI

ENTRY POINT
EP-A

PWS ID 4100323
GLENDALE, CITY OF

Sample period: February 2022
Month/Year

Number of excursions during this month: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative).
An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference
Minimum Water Quality Parameter(s) as set by State:
pH 7.3

Print Name: SEAN NECHERBORN
Signature: [Signature]
Date: 3/8/22

(No = N = Excursion) Total N's

Send to DWP within 10 days after end of sampling period