

Day	pH	Alk	Phos	Sili	Y/N
1	7.8	64			Y
2	7.9	60			Y
3	7.6	60			Y
4	8.0	64			Y
5	7.8	64			Y
6	8.1	64			Y
7	7.8	68			Y
8	7.9	64			Y
9	7.6	64			Y
10	7.7	64			Y
11	7.7	64			Y
12	7.8	64			Y
13	7.8	64			Y
14	8.0	64			Y
15	7.5	64			Y
16	7.8	64			Y
17	7.6	64			Y
18	8.0	64			Y
19	8.1	68			Y
20	8.1	64			Y
21	8.0	64			Y
22	7.7	68			Y
23	7.7	64			Y
24	7.7	68			Y
25	7.8	68			Y
26	7.6	68			Y
27	7.7	68			Y
28	7.6	68			Y
29	7.6	68			Y
30	7.6	68			Y
31	7.7	68			Y

<<Have minimums been met for this day?

County: Douglas Agency: REGI

ENTRY POINT

EP-A

PWS ID 4100323

GLENDALE, CITY OF

Sample period: March 2022
Month/Year

Number of excursions during this month: _____

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:

pH 7.3

Print Name: SEAN NEGERBON

Signature: [Signature]

Date: 4/7/22

(No = N = Excursion) Total N's 0

Send to DWP within 10 days after end of sampling period