

# Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.5	68			y
2	7.6	64			y
3	7.7	68			y
4	7.7	68			y
5	7.5	68			y
6	7.7	68			y
7	7.7	64			y
8	8	68			y
9	8.1	68			y
10	8.1	72			y
11	8.1	72			y
12	8	72			y
13	7.9	64			y
14	7.8	64			y
15	8	64			y
16	8	64			y
17	8	64			y
18	8.2	68			y
19	8	60			y
20	8.3	60			y
21	7.8	60			y
22	7.8	60			y
23	7.8	60			y
24	7.8	64			y
25	7.8	64			y
26	7.6	64			y
27	7.8	72			y
28	7.8	72			y
29	7.8	68			y
30	7.6	68			y
31					

<<Have minimums been met for this day?

**ENTRY POINT**

**EP-A**

**PWS ID 4100323**

**GLENDALE, CITY OF**

Sample Period: April 2022

(Month/Year)

Number of excursions during this month:

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution Excursions are cumulative.) An 'Excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

**Minimum Water Quality**

**Parameter(s) as set by State:**

**pH: 7.3**

Print Name: Sean Negherbon

Signature: 

Date: 5/3/22

(No= N=Excursion) **Total N's**

Send to DWP within 10 days after end of sampling period