

# Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.9	60			y
2	7.7	60			y
3	7.7	56			y
4	7.7	60			y
5	7.8	56			y
6	off	off			y
7	7.8	56			y
8	7.9	56			y
9	7.9	60			y
10	7.6	60			y
11	7.8	60			y
12	8.1	56			y
13	7.9	60			y
14	8	60			y
15	7.6	56			y
16	7.9	56			y
17	7.7	60			y
18	7.7	56			y
19	7.7	56			y
20	7.7	60			y
21	7.8	60			y
22	7.7	64			y
23	7.6	60			y
24	7.6	60			y
25	8.1	60			y
26	8.1	60			y
27	8	60			y
28	7.9	56			y
29	8	60			y
30	7.8	60			y
31	7.9	56			y

(No= N=Excursion) **Total N's**

<<Have minimums been met for this day?	<h2>ENTRY POINT</h2> <h3>EP-A</h3> <h2>PWS ID 4100323</h2> <h3>GLENDALE, CITY OF</h3> <p>Sample Period:                  (Month/Year)    may            2023</p>
---	--

Number of excursions during this month:

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution Excursions are cumulative.)  
 An 'Excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

<h3>Minimum Water Quality</h3> <p>Parameter(s) as set by State:</p> <h2>pH: 7.3</h2>
--

Print Name: Sean Negherbon  
 Signature: *S. Negherbon*  
 Date: 6/7/23

Send to DWP within 10 days after end of sampling period