

# Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.7	56			y
2	7.8	60			y
3	7.7	56			y
4	7.9	60			y
5	7.8	56			y
6	7.8	60			y
7	7.7	60			y
8	7.9	56			y
9	8	56			y
10	7.9	56			y
11	8	52			y
12	7.8	56			y
13	8	60			y
14	7.9	56			y
15	7.7	60			y
16	8	68			y
17	8	68			y
18	7.8	64			y
19	7.9	64			y
20	8.1	64			y
21	8	60			y
22	7.8	60			y
23	7.9	60			y
24	7.9	60			y
25	7.8	60			y
26	8	64			y
27	8.1	60			y
28	7.9	60			y
29	8.1	60			y
30	7.9	60			y
31	8	60			y

<<Have minimums been met for this day?

**ENTRY POINT**

**EP-A**

**PWS ID 4100323**

**GLENDALE, CITY OF**

Sample Period:

(Month/Year) **august 2023**

Number of excursions during this month:

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution Excursions are cumulative.)  
An 'Excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

**Minimum Water Quality**

**Parameter(s) as set by State:**

**pH: 7.3**

Print Name: **Sean Negherbon**

Signature: 

Date: **9/6/23**

Send to DWP within 10 days after end of sampling period

(No= N=Excursion) **Total N's**