

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.6	60			y
2	7.8	64			y
3	7.9	60			y
4	7.9	64			y
5	8	60			y
6	7.9	60			y
7	7.8	60			y
8	7.8	60			y
9	7.8	64			y
10	7.7	52			y
11	7.5	56			y
12	7.7	56			y
13	7.6	60			y
14	7.4	60			y
15	7.5	56			y
16	7.7	56			y
17	7.6	56			y
18	7.4	56			y
19	7.6	56			y
20	7.5	52			y
21	8	56			y
22	7.8	56			y
23	7.6	56			y
24	7.8	52			y
25	7.7	56			y
26	7.8	52			y
27	7.5	52			y
28	7.7	56			y
29	7.7	56			y
30	7.7	56			y
31	7.6	60			y

(No= N=Excursion) **Total N's**

<<Have minimums been met for this day?	<h2>ENTRY POINT</h2> <h3>EP-A</h3> <h2>PWS ID 4100323</h2> <h3>GLENDALE, CITY OF</h3> <p>Sample Period:</p> <p style="text-align: right;">(Month/Year) Jan 2024</p>
---	---


Number of excursions during this month:

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution Excursions are cumulative.) An 'Excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Minimum Water Quality

Parameter(s) as set by State:

pH: 7.3

Print Name: Sean Negherbon
 Signature: 
 Date: 2/7/24

Send to DWP within 10 days after end of sampling period