

# Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.8	52			y
2	7.8	52			y
3	7.9	60			y
4	7.6	56			y
5	7.8	56			y
6	7.6	60			y
7	8.1	68			y
8	7.6	64			y
9	7.8	60			y
10	7.6	64			y
11	7.8	64			y
12	7.6	60			y
13	7.7	60			y
14	7.8	64			y
15	7.5	56			y
16	7.8	56			y
17	8	64			y
18	7.7	60			y
19	7.5	60			y
20	7.6	60			y
21	7.7	64			y
22	7.6	64			y
23	7.4	64			y
24	7.7	64			y
25	7.7	64			y
26	7.9	60			y
27	7.6	56			y
28	7.8	60			y
29	7.9	60			y
30					
31					

(No= N=Excursion) **Total N's** 0

<<Have minimums been met for this day?	<h2>ENTRY POINT</h2> <h3>EP-A</h3> <h2>PWS ID 4100323</h2> <h3>GLENDALE, CITY OF</h3> <p>Sample Period:</p> <p style="text-align: right;">(Month/Year) FEB 2024</p>
---	---


Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution Excursions are cumulative.)  
 An 'Excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

### Minimum Water Quality

Parameter(s) as set by State:

## pH: 7.3

Print Name: Sean Negherbon  
 Signature:   
 Date: 3/4/24

Send to DWP within 10 days after end of sampling period