

# Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.8	60			y
2	7.8	64			y
3	7.7	64			y
4	7.7	60			y
5	7.8	60			y
6	7.6	64			y
7	7.9	64			y
8	8	64			y
9	7.7	64			y
10	7.5	64			y
11	7.8	64			y
12	7.7	56			y
13	7.6	64			y
14	7.7	64			y
15	7.3	60			y
16	7.4	64			y
17	7.4	64			y
18	7.7	68			y
19	7.7	64			y
20	7.6	60			y
21	7.8	60			y
22	7.7	60			y
23	7.6	60			y
24	7.6	60			y
25	7	60			y
26	7.7	60			y
27	7.9	60			y
28	8.1	60			y
29	7.9	64			y
30	7.8	64			y
31					

(No= N=Excursion) **Total N's** 0

<<Have minimums been met for this day?

**ENTRY POINT**

**EP-A**

**PWS ID 4100323**

**GLENDALE, CITY OF**

Sample Period:

(Month/Year) April 2024

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution Excursions are cumulative.)  
An 'Excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

**Minimum Water Quality**

**Parameter(s) as set by State:**

**pH: 7.3**

Print Name: Sean Negherbon

Signature: 

Date: 5/6/24

Send to DWP within 10 days after end of sampling period