

# Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.8	64			y
2	7.5	64			y
3	7.7	64			y
4	7.7	64			y
5	7.9	60			y
6	7.8	64			y
7	8.3	64			y
8	8.1	64			y
9	7.9	60			y
10	7.6	64			y
11	7.7	64			y
12	7.6	60			y
13	7.7	64			y
14	7.5	60			y
15	7.4	68			y
16	7.9	56			y
17	8.1	64			y
18	8.2	64			y
19	8.1	64			y
20	8	64			y
21	8	64			y
22	7.9	64			y
23	7.9	60			y
24	8	60			y
25	8	64			y
26	7.8	64			y
27	7.9	64			y
28	8.2	64			y
29	8.1	56			y
30	8.1	64			y
31	8	64			y
(No= N=Excursion) Total N's					0

<<Have minimums been met for this day?	<h2>ENTRY POINT</h2> <h3>EP-A</h3> <h3>PWS ID 4100323</h3> <h3>GLENDALE, CITY OF</h3> <p>Sample Period:</p> <p style="text-align: right;">(Month/Year)    May            2024</p>
--	---


Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution Excursions are cumulative.)  
 An 'Excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

### Minimum Water Quality

Parameter(s) as set by State:

## pH: 7.3

Print Name: Sean Negherbon  
 Signature:   
 Date: 6/17/24

Send to DWP within 10 days after end of sampling period