

# Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	8.2	52			y
2	8.1	52			y
3	8.1	56			y
4	7.9	56			y
5	7.8	52			y
6	8	56			y
7	7.9	60			y
8	7.8	60			y
9	7.8	52			y
10	7.7	56			y
11	7.7	52			y
12	7.8	56			y
13	7.9	56			y
14	7.9	52			y
15	7.9	52			y
16	8.1	52			y
17	8	56			y
18	8	56			y
19	7.9	56			y
20	7.8	56			y
21	7.8	56			y
22	7.9	52			y
23	8	52			y
24	8.1	56			y
25	7.7	56			y
26	7.8	56			y
27	7.8	56			y
28	7.8	56			y
29	7.8	56			y
30	7.7	60			y
31	7.9	60			y


(No= N=Excursion) **Total N's**

<<Have minimums been met for this day?	<h2>ENTRY POINT</h2> <h3>EP-A</h3> <h3>PWS ID 4100323</h3> <h3>GLENDALE, CITY OF</h3> <p>Sample Period:</p> <p style="text-align: right;">(Month/Year) August 2024</p>
--	--

Number of excursions during this month:

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution Excursions are cumulative.)  
 An 'Excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

<h3>Minimum Water Quality</h3> <p>Parameter(s) as set by State:</p> <h2>pH: 7.3</h2>
--

Print Name: Sean Negherbon  
 Signature:   
 Date: 9/6/24

Send to DWP within 10 days after end of sampling period