

Lead & Copper Rule Corrosion Control

| Day | pH | Alk | Phos | Sili | Y/N |
|-----|-----|-----|------|------|-----|
| 1 | 7.9 | 60 | | | y |
| 2 | 7.9 | 60 | | | y |
| 3 | 7.9 | 60 | | | y |
| 4 | 8 | 56 | | | y |
| 5 | 7.9 | 56 | | | y |
| 6 | 7.9 | 56 | | | y |
| 7 | 7.9 | 60 | | | y |
| 8 | 7.9 | 60 | | | y |
| 9 | 8.1 | 56 | | | y |
| 10 | 7.9 | 56 | | | y |
| 11 | 7.9 | 60 | | | y |
| 12 | 8 | 56 | | | y |
| 13 | 8 | 60 | | | y |
| 14 | 7.9 | 60 | | | y |
| 15 | 7.9 | 60 | | | y |
| 16 | 7.8 | 60 | | | y |
| 17 | 7.9 | 56 | | | y |
| 18 | 7.8 | 56 | | | y |
| 19 | 7.7 | 56 | | | y |
| 20 | 7.6 | 60 | | | y |
| 21 | 7.8 | 60 | | | y |
| 22 | 7.8 | 60 | | | y |
| 23 | 7.7 | 60 | | | y |
| 24 | 7.8 | 64 | | | y |
| 25 | 7.7 | 56 | | | y |
| 26 | 7.8 | 56 | | | y |
| 27 | 7.8 | 60 | | | y |
| 28 | 7.8 | 60 | | | y |
| 29 | 7.8 | 64 | | | y |
| 30 | 7.7 | 64 | | | y |
| 31 | 7.8 | 64 | | | y |

(No= N=Excursion) **Total N's**

<<Have minimums been met for this day?

ENTRY POINT

EP-A

PWS ID 4100323

GLENDALE, CITY OF

Sample Period:

(Month/Year) Dec 2025

Number of excursions during this month:

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution Excursions are cumulative.)
An 'Excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Minimum Water Quality

Parameter(s) as set by State:

pH: 7.3

Print Name: Marcus Brenen

Signature: *Marcus Brenen*

Date: 1/4/26

Send to DWP within 10 days after end of sampling period