

Day	pH	Alk	Phos	Other	Y/N
1	7.7	67			Y
2	7.9	64			Y
3	7.9	63			Y
4	7.9	61			Y
5	7.7	60			Y
6	7.9	64			Y
7	7.6	64			Y
8	7.9	67			Y
9	7.7	64			Y
10	7.5	64			Y
11	7.8	61			Y
12	7.6	61			Y
13	7.9	64			Y
14	7.9	65			Y
15	7.7	65			Y
16	7.8	68			Y
17	7.7	67			Y
18	7.7	63			Y
19	7.7	63			Y
20	7.7	68			Y
21	7.7	68			Y
22	7.0	67			Y
23	7.6	68			Y
24	7.7	64			Y
25	7.9	61			Y
26	8.0	60			Y
27	7.7	64			Y
28	7.8	64			Y
29	7.9	68			Y
30	7.9	64			Y
31					Y
(No = N = Excursion) Total N's					0

<<Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 41 

0	0	3	2	3
---	---	---	---	---

System Name: City of Glendale

Entry Point: EP-A

Sample Period: April 2021 Month/Year

Number of excursions\* during this month: 0  
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: \_\_\_\_\_  
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative )

*For OHA use only*

**Minimum Water Quality Parameters as set by**

pH

Alk  (Alkalinity)

PO4  (Orthophosphate)

Other  (\_\_\_\_\_)

Print Name: Michael Bollweg

Signature: Michael Bollweg

Date: 5.9.21

Send to DWP within 10 days after end of sampling period