

Day	pH	Alk	Phos	Other	Y/N
1	8.0	64			Y
2	8.1	52			Y
3	8.0	68			Y
4	8.1	64			Y
5	8.1	68			Y
6	7.8	64			Y
7	7.7	60			Y
8	8.0	68			Y
9	8.0	68			Y
10	8.0	68			Y
11	8.1	67			Y
12	8.0	64			Y
13	8.0	64			Y
14	8.0	64			Y
15	7.9	68			Y
16	8.1	68			Y
17	8.2	64			Y
18	8.1	64			Y
19	8.0	64			Y
20	8.1	64			Y
21	8.0	68			Y
22	8.0	68			Y
23	8.2	68			Y
24	8.0	68			Y
25	7.9	68			Y
26	7.9	68			Y
27	8.0	68			Y
28	7.9	64			Y
29	8.2	64			Y
30	8.1	68			Y
					0

(No = N = Excursion) **Total N's** 0

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41 0 0 3 2 3

**System Name:** City of Glendale

**Entry Point:** EP-A

**Sample Period:** September 2021 Month/Year

**Number of excursions\* during this month:** 0  
*(Count the number of days when any WQP was less than the minimum required)*

**Total excursions during the previous 5 months:** \_\_\_\_\_  
*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)*

*For OHA use only*

**Minimum Water Quality Parameters as set by**

pH	<input type="text" value=""/>	
Alk	<input type="text" value=""/>	(Alkalinity)
PO4	<input type="text" value=""/>	(Orthophosphate)
Other	<input type="text" value=""/>	(_____)

**Print Name:** Michael Bollweg

**Signature:** Michael Bollweg

**Date:** 10-8-21

Send to DWP within 10 days after end of sampling period

OHA - Drinking Water Program - Surface Water Quality Data Form							WTP-B	WTP-A
System Name: <u>City of Glendale</u>		ID#: <u>41-00323</u>		Month/Year: <u>Sep-21</u>		Disinfection <i>Giardia</i> Log Inactive:	0.5	
Minimum Cl <sub>2</sub> Residual at 1st Contact Time	Contact Time	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow	