

Day	pH	Alk	Phos	Other	Y/N
1	7.7	76			Y
2	7.9	72			Y
3	7.9	68			Y
4	7.8	72			Y
5	7.8	68			Y
6	7.8	72			Y
7	7.8	68			Y
8	7.9	72			Y
9	7.9	76			Y
10	7.7	72			Y
11	8.1	72			Y
12	8.0	68			Y
13	7.9	72			Y
14	8.0	76			Y
15	7.9	68			Y
16	7.8	68			Y
17	8.0	76			Y
18	8.0	72			Y
19	7.5	72			Y
20	7.9	72			Y
21	7.9	68			Y
22	7.9	72			Y
23	8.0	76			Y
24	7.9	72			Y
25	8.2	72			Y
26	7.9	76			Y
27	8.1	72			Y
28	8.0	76			Y
29	7.8	72			Y
30	8.0	72			Y
(No = N = Excursion) Total N's					0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

0	0	3	2	3
---	---	---	---	---

System Name: City of Glendale

Entry Point: EP-A

Sample Period: November 2021 Month/Year


Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH



 Alk

--

 (Alkalinity)
 PO4

--

 (Orthophosphate)
 Other

--

 (_____)

Print Name: Michael Bollweg

Signature: Michael Bollweg

Date: 12.10.21

Send to DWP within 10 days after end of sampling period