

# Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.8	68			y
2	7.7	72			y
3	8	68			y
4	8	64			y
5	7.9	68			y
6	8	68			y
7	7.9	64			y
8	8.2	72			y
9	8.2	72			y
10	8	68			y
11	8	64			y
12	8.1	64			y
13	8	68			y
14	8	68			y
15	8.2	68			y
16	8	68			y
17	7.9	64			y
18	7.6	68			y
19	7.7	64			y
20	7.5	68			y
21	7.6	68			y
22	8	68			y
23	7.8	68			y
24	7.5	68			y
25	7.5	68			y
26	7.5	72			y
27	7.7	72			y
28	8	64			y
29	8.3	72			y
30	8.2	68			y
31	8.2	68			y


(No= N=Excursion) **Total N's**

<<Have minimums been met for this day?	<b>ENTRY POINT</b>  <b>EP-A</b>  <b>PWS ID 4100323</b>  <b>GLENDALE, CITY OF</b>  Sample Period: (Month/Year)    may            2022
---	---

Number of excursions during this month:

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution Excursions are cumulative.)  
 An 'Excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

<b>Minimum Water Quality</b>  <b>Parameter(s) as set by State:</b>  <b>pH: 7.3</b>
--

Print Name: Sean Nogherbon  
 Signature:   
 Date: 6/5/22

Send to DWP within 10 days after end of sampling period