

# Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.7	68			y
2	7.7	72			y
3	7.8	68			y
4	8.2	72			y
5	8	68			y
6	7.9	68			y
7	7.8	68			y
8	7.8	68			y
9	7.7	68			y
10	7.9	68			y
11	8	72			y
12	7.5	68			y
13	7.7	64			y
14	7.7	64			y
15	7.4	64			y
16	7.7	68			y
17	7.7	68			y
18	7.8	68			y
19	7.6	64			y
20	7.8	60			y
21	7.6	64			y
22	7.8	68			y
23	7.6	64			y
24	7.7	64			y
25	7.6	68			y
26	7	68			y
27	7.8	64			y
28	7.6	68			y
29	7.8	68			y
30	7.7	64			y
31	7.8	68			y

(No= N=Excursion) **Total N's** 0

<<Have minimums been met for this day?	<h2>ENTRY POINT</h2> <h3>EP-A</h3> <h2>PWS ID 4100323</h2> <h3>GLENDALE, CITY OF</h3> <p>Sample Period:                  (Month/Year) July 2022</p>
---	---


Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution Excursions are cumulative.)  
 An 'Excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

### Minimum Water Quality

Parameter(s) as set by State:

## pH: 7.3

Print Name: Sean Negherbon  
 Signature:   
 Date: 8/8/22

Send to DWP within 10 days after end of sampling period