

## Water Quality Parameter Monitoring Form

## **Lead & Copper Rule Corrosion Control**

Day	рН	Alk	Phos	Other	Y/N
1	7.7				Y
2	7.5			обатайска тубацизинализи (укручног Ан	Y
3				Associated in the second of the second	
4					
5	7.4			en marie de majeria de majeria de principal de estra de la	Y
6					
7	7.6				Y
8	7.5	2			Y
9	7.5				Y
10					
11	7.5				Y
12					
13					
14	7.6				Y
15	7.6				Y
16					
17					
18					
19	7.5				Y
20	7.5				Y
21	7.5				Y
22	7.5				Y
23					
24					
25					
26					
27					
28					
29	7.7				Y
30					
31					
No = N = Excursion) Total N's				0	

< <have minimums<="" td=""><td colspan="5">ENTRY POINT</td></have>	ENTRY POINT						
been met for this day?	PWS ID: 41 0 0 3 2 9						
System Name: Nesika Ophir Water District							
Entry Poi	nt: EP-A						
Sample P	eriod: April 2021						
	Month/Year						

Number of excursions\* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative)

Minimum Water Quality Parameters as set by						
рН	7.1					
Alk	na	(Alkalinity)				
PO4	na	(Orthophosphate)				
Other	na					
		-				

Print Name: Eric Shearer					
Signature: The land					
Date: 05/06/2021					
Send to DWP within 10 days after end of sampling period					