

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.5				
2	7.3				
3	7.3				
4					
5	7.3				
6	7.4				
7	7.3				
8	7.2				
9	7.2				
10					
11	7.4				
12	7.3				
13	7.2				
14	7.4				
15	7.2				
16	7.3				
17					
18	7.3				
19	7.8				
20	7.2				
21	7.2				
22	7.2				
23	7.3				
24					
25					
26	7.2				
27	7.3				
28	7.2				
29	7.2				
30	7.2				
31	7.2				

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

System Name: Nesika Beach - OPHW Water Dist.

Entry Point: POE

Sample Period: July, 2021
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	<input type="text" value="7.2"/>	
Alk	<input type="text"/>	(Alkalinity)
PO4	<input type="text"/>	(Orthophosphate)
Other	<input type="text"/>	(_____)

Print Name: Eric Shearer

Signature: 

Date: 8-3-2021

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's

NBOWD Pumphouse Data

Month July 2021

6-30 Date	Water Meter	Total Gallons	487126 Hour Meter	Total Hours	GPM	Chlorine PPM	pH
1	575552	2030	48726.6	14	241	.39	7.5
2	577357	1405	48739.0	12.4	242	.33	7.3
3	580311	2954	48759.4	20.4	241	.38	7.35
4							
5	583024	2713	48778.2	18.8	240	.58	7.32
6	584904	1880	48791.1	12.9	242	.58	7.39
7	586865	1961	48804.7	13.6	240	.46	7.29
8	588546	1681	48816.3	11.6	241	.49	7.2
9	590668	2122	48830.9	14.6	242	.49	7.26
10							
11	594790	4122	48859.5	28.6	240		7.4
12	596344	1554	48870.2	10.7	242	1.39	7.3
13	598112	1768	48882.4	12.2	241	.64	7.23
14	599946	1834	48895.1	12.7	240	.6	7.37
15	601838	1892	48908.2	13.1	240	1.0	7.25
16	603650	1812	48920.7	12.5	241	.43	7.27
17							
18	607745	4095	48949.1	28.4	240	.84	7.32
19	609237	1492	48959.3	10.2	243	.29	7.77
20	611109	1872	48972.2	12.9	241	.68	7.2
21	612814	1705	48983.9	11.7	243	.41	7.2
22	615070	2256	48999.5	15.6	241	.57	7.2
23	617427	2357	49015.1	15.6	251	.62	7.3
24							
25							
26	625156	7,729	49069.3	54.2	237	.67	7.2
27	626986	1430	49079.2	9.9	240	1.20 ↓	7.3
28	628821	2235	49094.6	15.4	241	.41	7.2
29	630787	1966	49108.2	13.6	240	.55	7.2
30	632800	2013	49122.7	13.5	246	.48	7.24
31	633999	1109	49130.6	8.4	220	.41	7.2
Total							