

Day	pH	Alk	Phos	Other	Y/N
1	7.2				
2	7.2				
3	7.2				
4					
5	7.3				
6					
7	7.2				
8	7.2				
9	7.2				
10	7.2				
11					
12					
13	7.2				
14	7.2				
15	7.2				
16	7.2				
17	7.3				
18					
19	7.2				
20	7.3				
21	7.2				
22	7.4				
23	7.2				
24	7.3				
25	7.2				
26					
27	7.2				
28	7.3				
29	7.4				
30	7.4				
31					

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

System Name: Nesika Beach - Opier Water Dist.

Entry Point: EP-A

Sample Period: Sept - 2021
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH (Alkalinity)

Alk (Alkalinity)

PO4 (Orthophosphate)

Other (_____)

Print Name: Eric Shearer

Signature: *Eric Shearer*

Date: Oct - 4 - 2021

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's**

NBOWD Pumphouse Data

Month 09-21

691979

495367

Date	Water Meter	Total Gallons	Hour Meter	Total Hours	GPM	Chlorine PPM	pH
1	693677	1698	49542.4	11.7	241	.47	7.2
2	695727	2050	49556.5	14.1	242	.64	7.2
3	697500	1773	49568.8	12.3	240	.33	7.2
4							
5	701172	3672	49594.2	25.4	240	.22	7.3
6							
7	704648	3476	49618.2	24	241	.31	7.2
8	706374	1726	49630.2	12	239	1.9	7.2
9	708144	1770	49642.5	12.3	239	.93	7.2
10	709834	1690	49654.2	11.7	240	.88	7.2
11							
12							
13	714385	4551	49685.3	31.1	243	.26	7.2
14	715773	1388	49695.3	10	231	.36	7.2
15	717582	1809	49707.1	11.8	255	.39	7.2
16	718938	1356	49717.0	9.9	228	H6	7.2
17	720639	1701	49728.1	11.1	255	1.14↓	7.3
18							
19	725821	5182	49764.2	36.1	239	.28	7.2
20	727682	1861	49777.1	12.9	240	.40	7.3
21	728828	1146	49785.1	8	238	.35	7.2
22	730588	1760	49797.2	12.1	242	.25	7.4
23	732730	2142	49811.9	14.7	242	.44	7.2
24	734905	2175	49826.8	14.9	243	.7	7.3
25	738352	3447	49850.4	23.6	243	.96	7.2
26							
27	742043	3691	49876.0	25.6	240	.23	7.2
28	745524	3481	49900.0	24	241	1.5↓	7.3
29	746596	1066	49907.5	7.5	236	.43	7.4
30	748587	1922	49921.4	13.9	230	.46	7.4
31							
Total							