

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.2				Y
2					
3					
4	7.3				Y
5	7.2				Y
6	7.2				Y
7	7.3				Y
8	7.3				Y
9					
10					
11	7.3				Y
12	7.3				Y
13	7.3				Y
14	7.2				Y
15	7.3				Y
16	7.3				Y
17					
18	7.9				Y
19	7.2				Y
20	7.2				Y
21	7.3				Y
22	7.2				Y
23	7.2				Y
24	7.2				Y
25	7.2				Y
26	7.2				Y
27	7.3				Y
28	7.3				Y
29	7.4				Y
30	7.3				Y
31					

(No = N = Excursion) Total N's

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

System Name: Nesika Beach - other Water District

Entry Point: POE

Sample Period: Oct, 2021
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH (Alkalinity)

Alk (Alkalinity)

PO4 (Orthophosphate)

Other

Print Name: Eric Shearer

Signature: [Signature]

Date: 11-1-2021

Send to DWP within 10 days after end of sampling period

NBOWD Pumphouse Data

Month 10-21

Date	Water Meter	Total Gallons	Hour Meter	Total Hours	GPM	Chlorine PPM	pH
1	750708	2126	49930	14.7	241	.5	7.2
2							
3							
4	754585	3877	49963.2	27.1	238	.20	7.3
5	755755	1170	49971.4	8.2	237	.26	7.2
6	757305	1550	49982.1	10.7	241	.25	7.2
7	758750	1445	49992.2	10.1	238	.24	7.3
8	760233	1483	50002.5	10.3	239	.36	7.3
9							
10							
11	762962	2729	50021.1	18.6	244	.27	7.3
12	762962	0	50021.1	0	0	.54	7.3
13	765077	2115	50036.2	15.1	233	.23	7.3
14	766951	1874	50049.1	12.9	242	.31	7.2
15	769025	2074	50063.5	14.1	245	.5	7.3
16	771048	2023	50077.6	14.1	239	.52	7.3
17							
18	773778	2730	50096.7	19.1	238	1.13	7.9
19	775060	1282	50105.6	8.9	240	.43	7.2
20	776405	1345	50114.9	9.3	241	.49	7.2
21	777639	1234	50123.5	8.6	239	.63	7.3
22	779203	1564	50134.3	10.8	241	.60	7.2
23	780704	1501	50144.7	10.4	240	.86	7.2
24	782003	1299	50153.7	9	240	.25	7.2
25	783100	1097	50161.1	7.4	247	.42	7.2
26	785159	2050	50175.3	14.2	240	.54	7.2
27	787239	2082	50189.7	14.4	240	.73	7.3
28	788523	1284	50198.7	9	237	.62	7.3
29	789948	1425	50205.6	9.9	239	1.04	7.4
30	791303	1355	50218.0	9.4	240	.78	7.3
31							
Total							

NBOWD

Date 10-21

Soda Ash Per Water Added

	Gallons remaining	Gallons added	Gallons used	Soda ash added	PH	Initials	Comments
1	35	15	15	9	7.2	ES	80/80
2							
3							
4	25	25	25	15	7.3	ES	80/80
5	45	5	5	3	7.2	CB	80/80
6	45	5	5	3	7.2	CB	80/80
7	45	5	5	3	7.3	CB	80/80
8	45	5	5	3	7.3	CB	80/80
9							
10							
11	40	10	10	6	7.3	ES	80/80
12	50	0	0		7.3	CB	80/80
13	30	20	20	12	7.3	CB	80/80
14	30	20	20	12		ES	100/100
15	25	25	25	15	7.3	CP	80/80
16	25	25	25	12	7.3	CB	80/80
17							
18	35	15	15	9	7.8	ES	80/80
19	45	5	5	3	7.2	CB	80/80
20							
21	45	5	5	3	7.3	ES	
22	45	5	5	3	7.2	CB	80/80
23	45	5	5	3	7.2	CB	80/80
24	45	5	5	3	7.2	ES	80/80
25	45	5	5	3	7.2	ES	80/80
26	45	5	5	3	7.2	CB	80/80
27	45	5	5	3	7.3	ES	80/80
28	45	5	5	3	7.2	CB	80/80
29	45	5	5	3	7.3	CB	80/80
30	43	7	7	4	7.3	CB	80/80
31							