

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

| Day | pH | Alk | Phos | Other | Y/N |
|-----|-----|-----|------|-------|-----|
| 1 | 7.2 | | | | Y |
| 2 | 7.2 | | | | Y |
| 3 | 7.3 | | | | Y |
| 4 | 7.2 | | | | Y |
| 5 | | | | | |
| 6 | 7.3 | | | | Y |
| 7 | 7.2 | | | | Y |
| 8 | | | | | |
| 9 | 7.2 | | | | Y |
| 10 | | | | | |
| 11 | 7.2 | | | | Y |
| 12 | 7.3 | | | | Y |
| 13 | 7.3 | | | | Y |
| 14 | 7.4 | | | | Y |
| 15 | 7.3 | | | | Y |
| 16 | 7.3 | | | | Y |
| 17 | 7.2 | | | | Y |
| 18 | 7.3 | | | | Y |
| 19 | 7.1 | | | | Y |
| 20 | 7.4 | | | | Y |
| 21 | | | | | |
| 22 | 7.4 | | | | Y |
| 23 | 7.5 | | | | Y |
| 24 | 7.3 | | | | Y |
| 25 | | | | | |
| 26 | 7.2 | | | | Y |
| 27 | 7.2 | | | | Y |
| 28 | 7.3 | | | | Y |
| 29 | 7.3 | | | | Y |
| 30 | 7.4 | | | | Y |
| 31 | 7.3 | | | | Y |

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

System Name: Nesika Beach - Opur Water Dist.

Entry Point: Poc

Sample Period: Dec - 2021
Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH (Alkalinity)
Alk (Orthophosphate)
PO4 (_____
Other

Print Name: Eric Shearer

Signature: [Signature]

Date: 01-03-2022

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's

NBOWD Pumphouse Data

Month December 2021

839944

505543

| Date | Water Meter | Total Gallons | Hour Meter | Total Hours | GPM | Chlorine PPM | pH |
|-------|-------------|---------------|------------|-------------|-----|--------------|------|
| 1 | 841454 | 1510 | 505650 | 10.7 | 235 | 1.41 ↓ | 7.2 |
| 2 | 843318 | 1864 | 50577.8 | 12.8 | 242 | .77 | 7.2 |
| 3 | 845564 | 2246 | 50593.4 | 15.6 | 239 | .97 | 7.3 |
| 4 | 847624 | 2060 | 50607.8 | 14.4 | 238 | .90 | 7.24 |
| 5 | | | | | | | |
| 6 | 851532 | 3.908 | 50635.3 | 27.5 | 236 | 1.34 | 7.3 |
| 7 | 852791 | 1259 | 50644.1 | 8.8 | 238 | 1.64 | 7.2 |
| 8 | | | | | | | |
| 9 | 855708 | 2917 | 50664.5 | 20.4 | 238 | .2 | 7.25 |
| 10 | | | | | | | |
| 11 | 858870 | 3162 | 50686.6 | 22.1 | 238 | 1.43 ↓ | 7.2 |
| 12S | 860483 | 1623 | 50697.9 | 11.3 | 239 | .45 | 7.3 |
| 13M | 862099 | 1616 | 50709.1 | 11.2 | 240 | .71 | 7.38 |
| 14T | 863702 | 1603 | 50720.2 | 11.1 | 240 | .25 | 7.4 |
| 15W | 865347 | 1645 | 50731.5 | 11.3 | 242 | .78 | 7.3 |
| 16T | 867099 | 1752 | 50743.8 | 12.3 | 237 | .4 | 7.3 |
| 17F | 868633 | 1534 | 50754.4 | 10.6 | 241 | .3 | 7.2 |
| 18S | 870472 | 1839 | 50767.2 | 12.8 | 239 | 1.4 ↑ | 7.3 |
| 19S | 871975 | 1503 | 50777.6 | 10.4 | 240 | 1.4 | 7.1 |
| 20M | 873701 | 1726 | 50789.6 | 11 | 239 | .67 | 7.4 |
| 21T | | | | | | | |
| 22W | 877153 | 3452 | 50813.5 | 23.9 | 240 | .66 | 7.4 |
| 23T | 878882 | 1729 | 50825.4 | 11.9 | 242 | .43 | 7.5 |
| 24F | 880730 | 1848 | 50838.2 | 12.8 | 240 | 1.09 ↓ | 7.3 |
| 25S | | | | | | | |
| 26S | 884284 | 3354 | 50862.7 | 24.5 | 241 | .23 | 7.2 |
| 27M | 886026 | 1742 | 508748 | 12.1 | 239 | .27 | 7.2 |
| 28T | 887836 | 1810 | 508874 | 12.6 | 239 | .61 | 7.3 |
| 29W | 889662 | 1826 | 50900.0 | 12.6 | 241 | .61 | 7.3 |
| 30T | 891452 | 1790 | 50912.5 | 12.5 | 238 | .3 | 7.4 |
| 31F | 893248 | 1796 | 50925.0 | 12.5 | 239 | .45 | 7.3 |
| Total | | | | | | | |