

Day	pH	Alk	Phos	Other	Y/N
1	7.3	77			Y
2	7.5	88			Y
3	7.5	107			Y
4	7.3				Y
5	7.2				Y
6	7.2				Y
7	7.2	84			Y
8	7.3	89			Y
9	7.3				Y
10	7.2				Y
11	7.3	88			Y
12	7.2	90			Y
13	7.2	91			Y
14	7.2	84			Y
15	7.3	95			Y
16	7.4	95			Y
17	7.4	94			Y
18	7.4				Y
19	7.3				Y
20	7.4	89			Y
21	7.2	96			Y
22	7.2	88			Y
23	7.2	97			Y
24	7.3	86			Y
25	7.3				Y
26	7.3				Y
27	7.4	95			Y
28	7.3	92			Y
29	7.4	94			Y
30	7.4	94			Y
31					
					0

<<Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 41 

0	0	3	2	9
---	---	---	---	---

System Name: Nesika Beach Ophir Water

District \_\_\_\_\_

Entry Point: POE

Sample Period: September, 2022

Month/Year

Number of excursions\* during this month: 0  
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative )

For OHA use only

**Minimum Water Quality Parameters as set by**

pH 

--

  
 Alk 

--

 (Alkalinity)  
 PO4 

--

 (Orthophosphate)  
 Other 

--

 (\_\_\_\_\_)

Print Name: Eric Shearer

Signature: 

Date: 10/03/2022

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's







# NBOWD

Date September 2022

## Soda Ash Per Water Added

	Gallons		Gallons		PH	Initials	Comments
	remaining	added	used	added			
1	35	15	15	9	7.3		
2	38	12	12	5	7.5	ZD	
3	38	12	12	5	7.5	ZD	
4	40	10	10	6	7.3		
5	40	10	10	6	7.2		
6	35	15	15	9	7.2		
7	35	15	15	9	7.3		
8	35	15	15	9	7.2		65/85
9	35/40	15/10	15/10	6	7.2		
10							
11	40	5	5	3	7.3		
12	44	6	6	3	7.3		
13	38	12	12	7	7.2	ZD	
14	40	10	10	6	7.2		
15	40	10	10	6	7.3	ZD	
16	40	10	10	5	7.4	ZD	
17	42	8	8	3	7.4		
18	42	8	8	3	7.4		
19	40	10	10	6	7.3		
20	41	9	9	4	7.4	ZD	
21	45	5	5	3	7.2		
22	44	6	6	3	7.2	ZD	
23	40	10	10	6	7.3	ZD	
24	40	10	10	6	7.3		
25	38	12	12	8	7.3		
26	40	10	10	6	7.3		
27	44	6	6	3	7.4	ZD	
28							
29							
30	41	9	9	4	7.4	ZD	
31							

# NBOWD

Date September 2022

## Chlorine Per Water Added

	Gallons remaining	Gallons added	Gallons used	Chlorine added	PH	Initials	Comments
1	40	10	10	2	0.51		
2	44	5	6	1	0.45		
3	43	7	7	0	0.47		
4	43	7	7	1	.39		
5	44	6	6	1	.45		
6	41	9	9	1.5	.59		
7							
8	36	0	14	0	.63	ES	42/42
9	33	17	3	2			
10							
11	43	6	7	1.2	.85		
12	45	5	5	1	.53		
13	43	7	7	0	0.57		
14	43	7	7	1	.48		
15	43	6	7	1	0.55		
16	43	6	7	1	0.55		
17	43	7	7	0	0.64		
18	43	7	7	1	.56		
19	41	9	9	1	.63		
20	41	9	9	0	0.72		
21	43	6	7	1	.56		
22	43	6	7	1	0.47		
23	42	7	8	1	0.57		
24	42	7	8	1	0.65		
25	42	7	8	1	.51		
26	40	8	10	2	.55		
27	45	4	5	1	.30		
28	45	5	5	0	0.71		
29	42	7	8	1	0.62		
30	42	7	8	1	0.62		
31							

ESB  
(initials)