Oregon Health Authority

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.3				
2	7.3				
3	7.3				
4	7.3				
5	7.3				
6	7.3				
7	7.2				
8	7.3				
9	7.3				
10	7.3				
11					
12	7.3				
13	7.2				
14	7.2				
15	7.3				
16	7.4				
17	7.3				
18	7.3				
19	7.3				
20	7.3				
21	7.2				
22	7.2				
23	7.2				
24					
25	7.2				
26	7.2				
27	7.2				
28	7.1				
29	7.3				
30	7.1				
31					

(No = N = Excursion) **Total N's** 0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 0 0 3 2 9

System Name: Nesika Beach - Ophir Water Dist.

Entry Point: Poe

Sample Period: November / 2022
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH		
Alk		*(Alkalinity)*
PO4		*(Orthophosphate)*
Other		(_____)

Print Name: Eric Shearer

Signature: Eric Shearer

Date: 12-5-2022

Send to DWP within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone (971) 673-0405 Website: http://healthoregon.org/dwp/

NBOWD Pumphouse Data **Month** _____

Date	Water Meter	Total Gallons	Hour Meter	Total Hours	GPM	Chlorine PPM	pH	Alka
1								
2								
3								
4								
5								
6								
7	333384	1197	54017.7	8.6	232	.65		
8								
9	335646	1126	540		231	0.50		
10						0.66		93
11								
12		2207			235			
13			54065.5	8.1		0.70		
14			54073.4	7.9	237	.69		
15								
16								
17								
18								
19						0.57		89
20	348597	1211	54125.1	8.5	237	0.60	7.3	
21	349797	1200	54133.5	8.4	238	0.72	7.2	
22	351208	1411	54143.4	9.9	237	0.53	7.2	100
23	352682	1474	54153.8	10.4	236	0.60	7.2	92
24								
25	355217	2535	54171.6	17.8	237	0.60	7.2	88
26	356641	1424	54181.5	9.9	239	0.71	7.2	88
27	358188	1547	54192.4	10.9	236	0.61	7.2	
28	359790	1602	54203.8	11.4	234	0.73	7.1	
29	361486	1696	54215.5	11.7	241	0.64	7.3	84
30	362852	1366	54225.1	9.6	237	0.69	7.1	86
31								
Total								

NBOWD

Date November 2022

Soda Ash Per Water Added

	Gallons remaining	Gallons added	Gallons used	Soda ash added	PH	Initials	Comments
1	40	10	10	6	7.3		
2	44	6	6	3	7.3		
3	44	6	6	3	7.3		
4	44	6	6	3	7.3	ED	
5	46	4	4	2	7.3	ED	
6	46	4	4	2	7.3		
7	44	6	6	3	7.2		
8	45	5	5	3	7.3	ED	
9	46	4	4	2	7.3		
10							
11							
12	45	5	5	3	7.3	ED	
13	~~50~~	~~0~~	~~0~~	~~0~~	7.1		
14	45	5	5	3	7.1		
15	44	6	6	3	7.3		
16	47	3	3	0	7.1		
17	45	2	2	0	7.3		
18	39	6	6	0	7.3	ED	
19	37	2	2	0	7.3	ED	
20	35	15	2	9	7.3		
21	43	7	7	4	7.2	ED	
22	43	7	7	4	7.2	ED	
23							
24							
25	38	12	12	7	7.2	ED	
26	46	4	4	3	7.2	ED	
27	~~90~~ 90	10	10	6	7.2		
28	40	10	10	6	7.1	ED	
29	44	6	6	4	7.3		
30	44	6	6	4	7.1		
31							

NBOWD

Date NOVEMBER 2022

Chlorine Per Water Added

	Gallons remaining	Gallons added	Gallons used	Chlorine added	PH	Initials	Comments
1	40	8	10	2	0.62		
2	46	5.5	4	.5	.76		
3	46	5.5	4	.5	.55		
4	45	4.5	5	.5	0.59	ZD	
5	46	3.5	4	0.5	0.62	ZD	
6	46	3.5	4	0.5	.57		
7	45	4	5	1	.65		
8	45			0.5	0.52	ZD	
9	46	3	4	.5	.50		
10							
11							
12	40	9	10	1	0.63	ZD	
13	40	9	10	1	.70		
14	40	9	10	1	.69		
15	45	4	5	1	.57		
16	45	4	5	1	.66		
17	45	4	5	1	.62		
18	45	4	5	1	0.53	ZD	
19	45	4	5	1	0.57	ZD	
20	45	4.5	5	.5	.60		
21	45	4	5	1	.72		
22	44	5	6	1	0.60	ZD	
23	44	5	6	1	0.60	ZD	
24							
25	38	10	12	2	0.60	ZD	
26	44	6	6	1	0.71	ZD	
27	44	5	6	1	.61		
28	44	0	4	0	.73	CS	
29	35	12	9	3	.61		
30	44	5	4	1	.69		
31							