

Day	pH	Alk	Phos	Other	Y/N
1	7.17	84	N/A		Y
2					
3	7.24	88			Y
4					
5	7.17	84			Y
6	7.21	90			Y
7	7.13	82			Y
8	7.30	82			Y
9	7.17	82			Y
10					
11	7.11	82			Y
12	7.33	84			Y
13	7.36	90			Y
14	7.11	88			Y
15	7.10	82			Y
16					
17	7.13	90			Y
18	7.18	92			Y
19	7.13	85			Y
20	7.10	86			Y
21	7.12	84			Y
22	7.11	91			Y
23					
24	7.12	84			Y
25	7.11	82			Y
26	7.14	88			Y
27	7.21	86			Y
28	7.11	88			Y
29	7.30	89			Y
30					
n/a					
					Y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

0	0	3	2	9
---	---	---	---	---

System Name: Nesika Beach-Ophir WD

Entry Point: Pump House before Dist.

Sample Period: 

Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	<u>7.1</u>	
Alk	<u>73</u>	(Alkalinity)
PO4	<u>n/a</u>	(Orthophosphate)
Other	<u></u>	(_____)

Print Name: Melvin Troyer

Signature: 

Date: 10/3/2023

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0

SEPT 2023

Chlorine Per Water Added

	Gallons remaining	Gallons added	Gallons used	Chlorine added	Chlorine Residual	Initials	Comments
1	42	7 1/2	8	1/2	0.41	ZD	
2	32				0.36		
3	32	16	32	2	0.36	MT	
4							
5	32	16	32	2	0.41	MT	
6	40	9	10	1	0.46	ET	
7	39	10	11	1	0.42	MT	
8	38	10.5	12	1.5	0.40	MT	
9	45	4.75	5	0.25	0.47	MT	
10							
11	37	11.5	13	1.5	0.41	MT	
12	38	10.5	12	1.5	0.43	MT	
13	34	14.5	14	1.5	0.44	ZD	
14	40	9.5	10	.5	0.45	MT	
15	41	8.5	9	.5	0.40	ZD	
16	30	18.5	20	1.5	0.39	MT	
17	30	18	20	2	0.39	MT	
18	45	5	5	0	0.43	MT	Did not add chlor
19	32	16	18	2	0.46	ZD	
20	40	9	10	1	0.41	ZD	
21	40	9	10	1	0.40	ZD	
22	41	8	9	1	0.49	ZD	
23							
24	33	15	17	2	0.37	MT	
25	44	5 1/4	6	3/4	0.52	ET	
26	46	3 1/2	4 3/4	1/2	0.56	ZD	
27							
28	38	11	12	1	0.53	MT	
29	43	6 1/2	7	1/2	0.56	ZD	
30							
31							

NBOWD

Date SEPT 2023

Soda Ash Per Water Added

	Gallons remaining	Gallons added	Gallons used	Soda ash added	PH	Initials	Comments
1	38	12	12	7	7.17	ZD	
2	38	12	12	7	7.17	ZD	
3	25	25	25	15	7.24	M.T	
4	25	25	25	15	7.24	M.T	
5	25	25	25	15	7.17	M.T	
6	35	15	15	8	7.21	CT	
7	50	0	0	0	7.13	M.T	Pump Valve Break fixed M.T.
8	21	29	29	17	7.30	MT	
9	40	10	10	6	7.17	MT	
10							
11	38	12	12	7	7.11	MT	
12	37	13	13	7	7.33	MT	
13	39	11	11	7	7.36	ZD	
14	43	7	7	4	7.11	MT	
15	44	6	6	4	7.10	ZD	
16	44	6	6	4	7.10	ZD	
17	35	15	15	9	7.13	MT	
18	45	5	5	3	7.18	MT	
19	35/50	15/0	0/15	9/0	7.26	CT	
20	40	10	10	6	7.10	ZD	
21	40	10	10	6	7.12	ZD	
22	41	9	9	6	7.11	ZD	
23	41	9	9	6	7.11	ZD	
24	32	18	18	11	7.12	MT	
25	44	6	6	9	7.11	CT	
26	45	5	5	3	7.14	ZD	
27	45	5	5	3	7.14	ZD	
28	36	14	14	9	7.11	MT	
29	43	7	7	4	7.30	ZD	
30							
31							

