

NBOWD Pumphouse Data

Month FEB 2024

Date	Water Meter	Total Gallons	Hour Meter	Total Hours	GPM	Chlorine PPM	pH	Alka
1	38181	1166	58843.2	9.3	208	0.45	7.15	92
2	39169	798	58851.2	8.0	205	0.34	7.10	87
3	39770	601	58856.7	5.5	182	0.41	7.12	94
4	601							
5	41522	1752	58870.1	13.4	217	0.55	7.11	98
6	42440	918	58877.5	7.4	206	0.48	7.13	85
7	43302	862	58884.4	6.9	208	0.41	7.13	98
8	44163	861	58891.3	6.9	207	0.44	7.10	89
9	45338	1175	58900.7	9.4	208	0.57	7.10	84
10	46296	958	58908.4	7.7	207	0.40	7.23	86
11								
12	48111	1815	58923.1	14.7	205	0.54	7.10	92
13	49188	1077	58931.8	8.7	206	0.37	7.20	92
14	50290	1102	58940.6	8.8	208	0.58	7.18	88
15	51397	1107	58949.4	8.8	209	0.52	7.14	85
16	52491	1094	58958.2	8.8	207	0.43	7.16	88
17	53454	963	58965.9	7.7	208	0.29	7.29	92
18	54285	831	58972.5	6.6	209	0.33	7.12	89
19						0.40		
20	55931	1646	58985.8	13.3	206	0.40	7.17	82
21	56987	1056	58994.2	8.4	209	0.59	7.12	85
22	57872	885	59001.3	7.1	207	0.47	7.18	89
23	59054	1182	59010.8	9.5	207	0.46	7.12	86
24	59590	536	59015.1	4.3	207	0.50	7.14	92
25								
26	61641	2051	59031.8	16.7	204	0.27	7.10	94
27	62524	883	59038.8	7	210	0.53	7.12	88
28	63727	1203	59048.8	10	200	0.59	7.14	98
29								
30								
31								
total								

30 min off
6:40-1p

ADD 30 min

FEB 2024

Chlorine Per Water Added

	Gallons remaining	Gallons added	Gallons used	Chlorine added	Chlorine Residual	Initials	Comments
1	43	/	7	/	0.45	ZD	
2	37	12	6	1	0.34	ZD	
3	45	4 1/2	5	1/2	0.41	CT	
4							
5	40	9 1/2	10	1/2	0.55	CT	
6	46	/	4	/	0.48	ZD	
7	39	10 1/4	11	3/4	0.41	CT	
8	47	/	3	/	0.44	M.T.	
9	38	11	9	1	0.57	ZD	
10	44	⊖	6	⊖	0.40	M.T.	
11							
12	31	37 1/2	19	1 1/2	0.54	CT	
13	45	/	5	/	0.37	CT	
14	37	12	8	1	0.58	ZD	
15	44	/	6	/	0.52	ZD	
16	36	13	8	1	0.43	ZD	
17	45	4.5	5	.5	0.29	M.T.	
18	44	/	6	/	0.33	ZD	
19							
20	33	16	11	1	0.40	ZD	
21	44	/	6	/	0.59	ZD	
22	38	11	6	1	0.47	ZD	
23	44	/	6	/	0.46	ZD	
24	40	9 1/2	10	1/2	0.50	CT	
25					0.27	CT	
26	36	7	37 1/2	1 1/2	0.27	CT	
27	45	/	/	/	0.53	M.T.	
28	36	14	13 1/2	1/2	0.59	CT	
29							
30							
31							

NBOWD

Date FEB 2024

Soda Ash Per Water Added

No.	Gallons		Gallons		PH	Initials	Comments
	remaining	added	used	Soda ash added			
1	43	/	7	/	7.15	ZD	
2	35	15	8	9	7.10	ZD	
3	45	5	5	3	7.12	CT	
4					7.11		
5	43	7	7	6	7.11	CT	
6	47	/	3	/	7.13	ZD	
7	40	10	10	6	7.13	CT	
8	47	0	3	0	7.10	M.T.	
9	44	6	3	3	7.10	ZD	TURNED UP SPEED 70/70
10	46	0	4	0	7.24	M.T.	Turned up pressure
11					7.11		
12	34	16	16	9	7.10	CT	
13	45	/	5	/	7.20	CT	
14	40	10	5	6	7.18	ZD	
15	46	-	4	/	7.14	ZD	
16	41	9	5	6	7.14	ZD	
17	44	6	6	3.5	7.25	M.T.	
18	46	/	4	/	7.12	ZD	
19							
20	44	6	2	3	7.18	ZD	
21	29	21	21	13	7.12	ZD	TURNED DOWN TO 65/65
22	34	16	16	9	7.18	ZD	
23	36	14	14	9	7.12	ZD	TURNED DOWN TO 60/60
24	41	9	9	6	7.14	CT	
25							TURNED UP TO 65/65
26	30	20	20	12	7.10	CT	
27	36	14	14	9	7.12	M.T.	
28	35	15	15	9	7.14	CT	
29							
30							
31							

