

Lead & Copper Rule Corrosion Control

| Day | pH | Alk | Phos | Other | Y/N |
|-----|-----------------|-----|------|-------|-----|
| 1 | 7.17 | 83 | N/A | | Y |
| 2 | 7.20 | 88 | | | Y |
| 3 | 7.15 | 86 | | | Y |
| 4 | 7.12 | 98 | | | Y |
| 5 | 7.17 | 96 | | | Y |
| 6 | 7.34 | 92 | | | Y |
| 7 | 7.13 | 88 | | | Y |
| 8 | 7.21 | 90 | | | Y |
| 9 | 7.26 | 92 | | | Y |
| 10 | 7.18 | 90 | | | Y |
| 11 | 7.14 | 92 | | | Y |
| 12 | 7.22 | 96 | | | Y |
| 13 | 7.18 | 94 | | | Y |
| 14 | 7.18 | 78 | | | Y |
| 15 | 7.16 | 80 | | | Y |
| 16 | | | | | |
| 17 | 7.33 | 84 | | | Y |
| 18 | 7.15 | 86 | | | Y |
| 19 | 7.11 | 84 | | | Y |
| 20 | 7.31 | 85 | | | Y |
| 21 | 7.10 | 86 | | | Y |
| 22 | 7.15 | 87 | | | Y |
| 23 | 7.15 | | | | |
| 24 | 7.11 | 88 | | | Y |
| 25 | 7.10 | 86 | | | Y |
| 26 | 7.12 | 84 | | | Y |
| 27 | 7.11 | 82 | | | Y |
| 28 | 7.15 | 88 | | | Y |
| 29 | 7.13 | 89 | | | Y |
| 30 | 7.11 | 88 | | | Y |
| 31 | 7.20 | 90 | | | Y |

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 0 0 3 2 9

System Name: Nesika Beach-Ophir WD

Entry Point: Pump House before Dist.

Sample Period: March 2024

Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

| | | |
|-------|-----|------------------|
| pH | 7.1 | |
| Alk | 73 | (Alkalinity) |
| PO4 | n/a | (Orthophosphate) |
| Other | | (_____) |

Print Name: Melvin Truitt

Signature: [Signature]

Date: 4/3/2024

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0

NBOWD Pumphouse Data

Month March 2024

| Date | Water Meter | Total Gallons | Hour Meter | Total Hours | GPM | Chlorine PPM | pH | Alka |
|-------|-------------|---------------|------------|-----------------|-----|-----------------|------|------|
| 1 | 65228 | 1501 | 59060.8 | 12 | 208 | 0.52 | 7.17 | 83 |
| 2 | 66264 | 1036 | 59069.0 | 8.2 | 210 | 0.46 | 7.20 | 88 |
| 3 | 66807 | 607 | 59073.4 | 4.4 | 229 | 0.46 | 7.5 | 86 |
| 4 | 67989 | 1182 | 59082.8 | 9.4 | 209 | 0.60 | 7.12 | 98 |
| 5 | 69055 | 1066 | 59091.9 | 9.1 | 195 | 0.55 | 7.17 | 96 |
| 6 | 70048 | 933 | 59100.1 | 8.2 | 190 | 0.43 | 7.34 | 92 |
| 7 | 71091 | 1043 | 59108.7 | 8.6 | 202 | 0.33 | 7.13 | 88 |
| 8 | 72042 | 951 | 59115.9 | 7.2 | 220 | 0.56 | 7.21 | 90 |
| 9 | 73305 | 1263 | 59126.1 | 10.2 | 206 | 0.33 | 7.26 | 92 |
| 10 | 75269 | 1964 | 59141.6 | 15.5 | 211 | 0.54 | 7.18 | 90 |
| 11 | 75929 | 659 | 59146.9 | 5.3 | 207 | 0.33 | 7.14 | 92 |
| 12 | 77054 | 1126 | 59155.9 | 9 | 208 | 0.49 | 7.22 | 96 |
| 13 | 78015 | 961 | 59163.8 | 7.9 | 202 | 0.61 | 7.18 | 94 |
| 14 | 78898 | 883 | 59170.66 | 6.86 | 214 | 0.55 | 7.18 | 78 |
| 15 | 79870 | 972 | 59176.48 | 7.82 | 207 | 0.63 | 7.16 | 80 |
| 16 | | | | | | | | |
| 17 | 81728 | 1858 | 59193.38 | 14.9 | 207 | 0.59 | 7.33 | 84 |
| 18 | 82676 | 948 | 59201.02 | 7.64 | 207 | 0.59 | 7.15 | 86 |
| 19 | 83812 | 1136 | 59210.13 | 9.11 | 207 | 0.58 | 7.11 | 84 |
| 20 | 84837 | 1025 | 59218.35 | 8.22 | 208 | 0.53 | 7.31 | 85 |
| 21 | 85840 | 1003 | 59226.39 | 8.04 | 207 | 0.48 | 7.10 | 86 |
| 22 | 86924 | 1084 | 59235.07 | 8.68 | 208 | 0.52 | 7.15 | 87 |
| 23 | | | | | | | | |
| 24 | 88823 | 1899 | 59250.34 | 15.27 | 207 | 0.46 | 7.11 | 88 |
| 25 | 89820 | 997 | 59258.27 | 7.93 | 209 | 0.47 | 7.10 | 86 |
| 26 | 90797 | 977 | 59266.10 | 7.83 | 208 | 0.48 | 7.12 | 84 |
| 27 | 92034 | 1237 | 59275.96 | 9.86 | 209 | 0.56 | 7.11 | 82 |
| 28 | 93117 | 1083 | 59284.67 | 8.71 | 207 | 0.53 | 7.15 | 88 |
| 29 | 94478 | 1361 | 59295.84 | 10.76 | 210 | 0.50 | 7.13 | 89 |
| 30 | 95058 | 580 | 59300.09 | 7.91 | 203 | 0.49 | 7.11 | 88 |
| 31 | 96052 | 994 | 59308.10 | 7.91 | 209 | 0.43 | 7.20 | 90 |
| total | | | | | | | | |

M.T.

1230 PM
D.P. 6A-23

6A-139P

6A-115.

6A-1P

6A-115P

6A-145P

6A-215P

6A-145P

6A-115P

6A-145P

6A-2P

6A-215P

6A-145P

6A-130

6A-145

NBOWD

Date MARCH 2024

Soda Ash Per Water Added

| | Gallons remaining | Gallons added | Gallons used | Soda ash added | PH | Initials | Comments |
|----|-------------------|-----------------|-----------------|----------------|------|----------|-------------|
| 1 | 30 | 20 | 20 | 12 | 7.17 | ZD | |
| 2 | 45 | 0 | 5 | 0 | 7.20 | M.T | |
| 3 | 40 42 | 20 8 | 20 3 | 5 | 7.15 | M.T | |
| 4 | | | | | 7.12 | CT | |
| 5 | 40 | 10 | 10 | 6 | 7.17 | CT | |
| 6 | | | | | 7.34 | CT | |
| 7 | 36 | 4 | 4 | 3 | 7.13 | CT | |
| 8 | 40 46 | 0 | 0 46 | 0 | 7.21 | M.T | repair pump |
| 9 | 39 | 11 | 11 | 6 | 7.26 | CT | |
| 10 | 35 | 15 | 15 | 9 | 7.18 | M.T | |
| 11 | | | | | 7.14 | CT | |
| 12 | 37 | 13 | 13 | 7 | 7.22 | CT | |
| 13 | | | | | 7.18 | CT | |
| 14 | 38 | 12 | 12 | 7 | 7.18 | M.T | |
| 15 | 44 | | | | 7.16 | M.T | |
| 16 | | | | | | | |
| 17 | 30 | 20 | 20 | 12 | 7.33 | M.T | |
| 18 | 44 | | | | 7.15 | M.T | |
| 19 | 35 | 15 | 15 | 9 | 7.11 | M.T | |
| 20 | | | | | 7.10 | | |
| 21 | 36 | 14 | 16 | 9 | 7.10 | M.T | |
| 22 | 45 | 5 | 5 | 3 | 7.15 | ZD | |
| 23 | | | | | | | |
| 24 | 38 | 12 | 12 | 7.05 | 7.11 | M.T | |
| 25 | 44 | / | 6 | / | 7.10 | M.T | |
| 26 | 36 | / | 8 | / | 7.12 | M.T | |
| 27 | 28 | 22 | 8 | 13 | 7.11 | ZD | |
| 28 | 44 | / | 6 | / | 7.15 | ZD | |
| 29 | 34 | 16 | 10 | 10 | 7.13 | ZD | |
| 30 | 46 | / | 4 | / | 7.11 | M.T | |
| 31 | 42 | / | 4 | / | 7.20 | M.T | |

MARCH 2024

Chlorine Per Water Added

| | Gallons remaining | Gallons added | Gallons used | Chlorine added | Chlorine Residual | Initials | Comments |
|----|-------------------|---------------|---------------|----------------|-------------------|----------|---------------------|
| 1 | 41 | 8 | 9 | 1 | 0.52 | ZD | |
| 2 | 44 | 0 | 6 | 0 | 0.46 | M.T. | |
| 3 | 40 | 9 | 4 | 1 | 0.46 | M.T. | |
| 4 | | | | | 0.60 | CT | |
| 5 | 35 | 13 1/2 | 15 | 1 1/2 | 0.33 | CT | 0.52 |
| 6 | | | | | 0.43 | CT | |
| 7 | 40 | 9 | 10 | 1 | 0.33 | CT | |
| 8 | 45 | 0 | 5 | 0 | 0.56 | M.T. | |
| 9 | 36 | 12 1/2 | 14 | 1 1/2 | 0.33 | CT | |
| 10 | 40 | 9 | 10 | 0 1 | 0.54 | M.T. | |
| 11 | | | | | 0.33 | CT | |
| 12 | 37 | 11 3/4 | 13 | 1 1/4 | 0.49 | CT | |
| 13 | 39 | 10 | 11 | 1 | 0.61 | CT | |
| 14 | 39 | 10 | 11 | 1 | 0.55 | M.T. | |
| 15 | 44 | | | | 0.63 | M.T. | |
| 16 | <hr/> | | | | | | |
| 17 | 33 | 15.25 | 17 | 1.75 | 0.59 | M.T. | |
| 18 | 45 | | | | 0.59 | M.T. | |
| 19 | 37 | 12 | 13 | 1 | 0.58 | M.T. | ← Pump Brake repair |
| 20 | <hr/> | | | | | | |
| 21 | 45 | | 5 | | 0.48 | M.T. | |
| 22 | 40 | 9 | 5 | 1 | 0.52 | ZD | |
| 23 | <hr/> | | | | | | |
| 24 | 38 | 11 | 12 | 1 | 0.46 | M.T. | |
| 25 | 45 | | 5 | | 0.47 | M.T. | |
| 26 | 38 | | 7 | | 0.48 | M.T. | |
| 27 | 30 | 18 | 8 | 2 | 0.56 | ZD | |
| 28 | 44 | | 6 | | 0.53 | ZD | |
| 29 | 35 | 13.5 | 9 | 1.5 | 0.50 | ZD | |
| 30 | 45 | | 5 | | 0.49 | M.T. | |
| 31 | 40 | | 5 | | 0.43 | M.T. | |

24/12

NDOWD Morning Rounds

Date:

Ward 2024

| | Stark W. Pump | Stark W. Total | Hori Tank | Horizon Pump | Hori Total | Graigis C. Meter | Graigis C. Total | Miller Pump | Miller Total | Ophir Meter | Ophir Total | Adarr Tank | Oldcoast Meter | Oldcoast Total | Men Tank |
|----|---------------|----------------|-----------|--------------|------------|------------------|------------------|-------------|--------------|-------------|-------------|------------|----------------|----------------|----------|
| 1 | | | | | | 801500 | 11,600 | | | | | | | | |
| 2 | 2127 | 2 | 36 1/2 | 2039350 | 1810 | 801300 | 2030 | 2542 | 3 | 52221 | 51000 | 23 1/4 | 17292 | 6800 | 26 1/2 |
| 3 | | | | | | | | | | | | | | | |
| 4 | 2130 | 3 | 36 3/4 | 2059220 | 1570 | 802180 | 4600 | 2545 | 3 | 52272 | 41000 | 23 1/2 | 172358 | 6600 | 26 1/2 |
| 5 | 2130 | 0 | 37 1/4 | 2042820 | 610 | 802410 | 2420 | 2546 | 1 | 52281 | 25000 | 21 | 172399 | 4100 | 25 1/2 |
| 6 | 2132 | 2 | 36 3/4 | 2040230 | 300 | 802640 | 2330 | 2547 | 2 | 522911 | 24000 | 23 1/2 | 172432 | 3300 | 25 1/2 |
| 7 | 2132 | 0 | 37 | 2040960 | 310 | 8029120 | 2680 | 2549 | 2 | 522935 | 24000 | 23 1/2 | 172461 | 2900 | 25 1/2 |
| 8 | | | | | | 8031790 | 2670 | | | 522954 | 19000 | 22 | 172491 | 2000 | 24 1/2 |
| 9 | 2135 | 3 | 35 1/2 | 2044100 | 3020 | 8034170 | 2380 | 2652 | 3 | 522977 | 23000 | 21 | 172513 | 2200 | 25 1/2 |
| 10 | | | | | | | | | | | | | | | |
| 11 | 2137 | 2 | 37 1/2 | 2045540 | 1200 | 8039280 | 5110 | 2655 | 3 | 523057 | 60000 | 24 | 172572 | 6500 | 26 |
| 12 | 2137 | 2 | 37 1/4 | 2046280 | 700 | 8041610 | 2230 | 2656 | 1 | 523060 | 23000 | 21 | 172613 | 3500 | 25 |
| 13 | 2137 | 0 | 38 | 20440240 | 160 | 8043240 | 2330 | 2658 | 2 | 523082 | 22000 | 21 | 172646 | 3100 | 25 1/2 |
| 14 | 2139 | 2 | 38 | 2043600 | 610 | 8046120 | 2290 | 2659 | 1 | 523107 | 25000 | 24 1/2 | 172699 | 5900 | 27 |
| 15 | 2139 | 0 | 38 | 2048200 | 700 | 8048450 | 2330 | 2660 | 1 | 523125 | 18000 | 21 1/4 | 172706 | 7000 | 27 |
| 16 | | | | | | | | | | | | | | | |
| 17 | 2142 | 3 | 37 | 2048940 | 610 | 8053700 | 5250 | 2663 | 3 | 523170 | 45000 | 23 1/2 | 172771 | 8000 | 28 1/2 |
| 18 | 2144 | 2 | 36 1/4 | 2051620 | 610 | 8056510 | 2810 | 2665 | 2 | 523195 | 25000 | 23 | 172807 | 9000 | 28 1/2 |
| 19 | 2144 | 0 | 37 1/4 | 2050810 | 690 | 8058960 | 2460 | 2666 | 1 | 523222 | 27000 | 23 1/2 | 172840 | 3800 | 25 1/2 |
| 20 | 2146 | 2 | 37 1/4 | 2050710 | 680 | 8061460 | 2440 | 2668 | 2 | 523250 | 28000 | 23 3/4 | | | 25 1/2 |
| 21 | 2146 | 0 | 38 | 2051640 | 670 | 8063930 | 2530 | 2669 | 1 | 523277 | 27000 | 24 | 172912 | 7200 | 26 1/2 |
| 22 | 2146 | 0 | 36 1/2 | 2052290 | 650 | 8066550 | 2920 | 2670 | 1 | 523294 | 17000 | 23 | 172957 | 4500 | 25 1/2 |
| 23 | | | | | | | | | | | | | | | |
| 24 | 2149 | 3 | 36 1/2 | 2052980 | 640 | 8070610 | 4060 | 2673 | 3 | 523738 | 44000 | 22 1/2 | 173024 | 6700 | 26 1/2 |
| 25 | 2151 | 2 | 36 | 2053650 | 670 | 8073170 | 2260 | 2675 | 2 | 523763 | 25000 | 20 1/4 | 173061 | 3700 | 25 1/2 |
| 26 | | | | | | | | | | | | | | | |
| 27 | 2151 | 0 | 37 | 2055020 | 1370 | 8077770 | 4600 | 2679 | 4 | 523417 | 54000 | 23 1/2 | 173133 | 7200 | 25 1/2 |
| 28 | 2154 | 3 | 37 1/2 | 2055300 | 700 | 8080360 | 2590 | 2681 | 2 | 523444 | 27000 | 23 1/4 | 173171 | 3800 | 26 |
| 29 | 2154 | 0 | 37 1/2 | 2056410 | 690 | 8083160 | 2800 | 2683 | 2 | 523470 | 26000 | 21 1/4 | 173238 | 6000 | 26 1/2 |
| 30 | 2162 | 13 | 37 | 2056710 | 0 | 8085750 | 2190 | 2684 | 1 | 523498 | 29000 | 25 1/2 | 173261 | 2300 | 25 1/2 |
| 31 | 2162 | 0 | 37 1/2 | 2057160 | 690 | 8087920 | 2570 | 2687 | 3 | 523522 | 24000 | 25 1/2 | 173305 | 4400 | 25 1/2 |

815
24/12/24

March 2024

NBOWD Morning Rounds Date:

| | I Hills 1 | | I Hills 2 | | I Hills 3 | | I Hills 3 | | S. Rid | | Osprey | | Quail Mt. | |
|----|-----------|--------|-----------|-------|-----------|-------|-----------|---------|--------|--------|--------|------|-----------|-------|
| | Pump 1 | Pump 2 | Pump 1 | Total | Meter | Total | Pump 1 | Pump 2 | Total | Tank | Tank | Tank | Pump | Total |
| 1 | 133117 | 85712 | | 2 | | | | | | | | | | |
| 2 | 133117 | 85712 | 7681.1 | 2.6 | 487584 | 8600 | 19943.0 | 21056.2 | 3.4 | 13/4 | 16 | | 22658.7 | 0.9 |
| 3 | | | | | | | | | | | | | | |
| 4 | 133138 | 85712 | 7681.1 | 2.1 | 487668 | 8400 | 19943.0 | 21059.7 | 3.5 | 11 1/2 | 16 | | 22659.1 | 0.9 |
| 5 | 133160 | 85712 | 7683.8 | 2.2 | 487757 | 8900 | 19943.0 | 21061.7 | 2.0 | 12 | 16 | | 22658.0 | 0.7 |
| 6 | 133189 | 85712 | 7683.8 | 2.9 | 487839 | 8200 | 19943.0 | 21063.4 | 1.5 | 11 1/2 | 16 | | 22660.3 | 0.5 |
| 7 | 133201 | 85712 | 7686.8 | 1.2 | 487927 | 8200 | 19943.0 | 21065.3 | 1.9 | 14 | 16 | | 22660.9 | 0.6 |
| 8 | 133219 | 85712 | 7696.9 | 1.8 | 488010 | 8300 | | | | | | | | |
| 9 | 133239 | 85712 | 7688.9 | 1.9 | 488091 | 8100 | 19943.0 | 21068.8 | 3.5 | 12 | 16 | | 22662.1 | 1.2 |
| 10 | 133261 | 85712 | | | | | | | | | | | | |
| 11 | 133261 | 85712 | 7688.9 | 2.3 | 488203 | 11200 | 19943.0 | 21072.4 | 3.6 | 11 1/2 | 15.2 | | 22662.5 | 0.4 |
| 12 | 133285 | 85712 | 7681.5 | 2.4 | 488286 | 8300 | 19943.0 | 21074.1 | 1.7 | 12 | 16 | | 22663.4 | 0.9 |
| 13 | 133307 | 85712 | 7681.5 | 2.2 | 488370 | 8400 | 19943.0 | 21075.9 | 1.8 | 11 3/4 | 16 | | 22663.9 | 0.5 |
| 14 | 133310 | 85712 | 7672.0 | 0.3 | 488406 | 3600 | 19943.0 | 21077.6 | 1.7 | 11 3/4 | 15 | | | |
| 15 | 133327 | 85712 | 7674.6 | 1.7 | 488453 | 4700 | 19943.0 | 21077.4 | 1.8 | 11 3/4 | 15 | | 22667.9 | 1.0 |
| 16 | | | | | | | | | | | | | | |
| 17 | 133374 | 85712 | 7676.8 | 4.7 | 488454 | 20100 | 19943.0 | 21082.9 | 3.5 | 12 | 16 | | 22666.0 | 1.1 |
| 18 | 133391 | 85712 | 7691.4 | 2.4 | 488474 | 8500 | 19943.0 | 21084.7 | 1.9 | 12 3/4 | 16 | | 22666.9 | 0.4 |
| 19 | 133398 | 8581.2 | 7691.4 | 2.0 | 488489 | 8000 | 19943.0 | 21084.7 | 2.2 | 12 3/4 | 16 | | 22666.9 | 0.5 |
| 20 | 133398 | 8589.3 | 7702.0 | 2.1 | 488705 | 8600 | 19947.2 | 21084.7 | 2.0 | 13 3/4 | 16 | | 22668.8 | 0.5 |
| 21 | 133398 | 8589.3 | 7702.0 | 2.2 | 488905 | 80 | 19949.2 | 21084.7 | 2.0 | 13 3/4 | 15.5 | | 22668.8 | 0.5 |
| 22 | 133398 | 8585.5 | 7702.0 | 2.2 | 488929 | 9400 | 19951.2 | 21084.7 | 2.0 | 12 3/4 | 16 | | 22668.8 | 0.5 |
| 23 | | | | | | | | | | | | | | |
| 24 | 133398 | 8588.0 | 7705.0 | 2.6 | 489097 | 11800 | 19951.7 | 21084.7 | 0.5 | 12 | 16 | | 22669.2 | 1.0 |
| 25 | 133398 | 8571.2 | 7705.0 | 3.2 | 489110 | 11300 | 19953.2 | 21084.7 | 1.5 | 13 3/4 | 16.1 | | 22670.4 | 1.1 |
| 26 | | | | | | | | | | | | | | |
| 27 | 133398 | 8593.7 | 7708.2 | 2.5 | 489213 | 10300 | 19956.1 | 21084.7 | 1.4 | 12 3/4 | 16 | | 22671.0 | 0.5 |
| 28 | 133398 | 8595.9 | 7708.2 | 2.2 | 489419 | 10600 | 19958.1 | 21084.7 | 2.0 | 13 3/4 | 15 | | 22671.9 | 0.5 |
| 29 | 133398 | 8576.6 | 7708.2 | 0.7 | 489499 | 80 | 19960.1 | 21084.7 | 2.0 | 11 3/4 | 16 | | 22672.3 | 0.4 |
| 30 | 133398 | 8594.1 | 7711.6 | 2.2 | 489576 | 10700 | 19961.9 | 21084.7 | 1.7 | 13 | 16 | | 22672.7 | 0.4 |
| 31 | 133398 | 8600.7 | 7711.6 | 2.9 | 489608 | 7600 | 19962.7 | 21084.7 | 1.9 | 13 3/4 | 15 1/2 | | 22675.2 | 0.5 |

Pumping

Run

Run

Small

