

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.30	80	N/A		Y
2	7.36	77			Y
3	7.35	78			Y
4	7.14	80			Y
5	7.40	80			Y
6	7.51	82			Y
7	7.39	82			Y
8	7.31	82			Y
9	7.25	84			Y
10	7.25	76			Y
11	7.12	80			Y
12	7.20	82			Y
13	7.24	84			Y
14	7.20	84			Y
15	7.24	84			Y
16	7.10	81			Y
17	7.12	82			Y
18	7.24	82			Y
19	7.61	82			Y
20	7.64	82			Y
21	7.57	82			Y
22	7.47	82			Y
23	7.31	74			Y
24	7.39	78			Y
25	7.43	75			Y
26	7.48	78			Y
27	7.50	82			Y
28	7.40	80			Y
29	7.27	76			Y
30	7.37	74			Y
31	7.34	78			Y
					N

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

0	0	3	2	9
---	---	---	---	---

System Name: Nesika Beach-Ophir WD

Entry Point: Pump House before Dist.

Sample Period: August 2024

Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	7.1	
Alk	73	(Alkalinity)
PO4	n/a	(Orthophosphate)
Other		(_____)

Print Name: Melvin Trover

Signature: 

Date: 09/05/2024

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's

NBOWD Pumphouse Data

Month AUGUST 2024

Date	Water Meter	Total Gallons	Hour Meter	Total Hours	GPM	Chlorine PPM	pH	Alka
1	271397	1773	60729.98	14.50	204	0.61	7.30	80
2	273091	1694	60743.90	13.92	203	0.41	7.36	77
3	275598	1507	60756.30	12.40	202	0.45	7.35	78
4	276012	1414	60767.90	11.60	203	0.55	7.14	80
5	277696	1684	60781.13	13.23	212	0.40	7.40	80
6	279321	1625	60795.43	14.30	189	0.40	7.57	82
7	280992	1671	60808.75	13.32	209	0.58	7.39	82
8	282624	1632	60822.11	13.36	204	0.41	7.31	82
9	284365	1741	60836.29	14.18	205	0.41	7.25	84
10	286022	1657	60849.57	13.58	203	0.39	7.25	76
11	287731	1709	60860.35	13.98	204	0.37	7.12	80
12	289146	1415	60875.14	11.29	209	0.39	7.20	82
13	291096	1950	60891.47	16.33	199	0.34	7.23	84
14	292803	1707	60905.47	14.00	203	0.47	7.20	84
15	294526	1723	60919.71	14.24	202	0.35	7.24	84
16	296191	1665	60933.37	13.66	203	0.39	7.10	81
17	297575	1384	60944.30	10.93	211	0.31	7.12	82
18	299179	1604	60958.11	13.81	194	0.40	7.24	82
19	300717	1534	60970.81	12.70	201	0.40	7.61	82
20	302397	1680	60984.32	13.51	207	0.53	7.64	82
21	303520	1123	60993.75	9.43	193	0.46	7.57	82
22	304789	1269	61004.14	10.39	204	0.43	7.47	82
23	306148	1359	61015.36	11.22	202	0.37	7.31	74
24	307280	1140	61024.78	9.42	202	0.46	7.39	78
25	308694	1406	61036.76	11.58	202	0.35	7.43	75
26	310108	1414	61047.94	11.63	202	0.41	7.48	78
27	311399	1291	61058.64	10.65	202	0.40	7.50	82
28	312784	1385	61070.21	11.57	200	0.66	7.40	80
29	314085	1301	61080.92	10.71	202	0.38	7.27	76
30	315569	1484	61093.17	12.25	202	0.39	7.37	74
31	316858	1289	61103.83	10.66	201	0.38	7.34	78
Total								

4-9
4-10
4-10
7.9
7.9
7.6
7.8
7.8 4-10
8.0 4-10
7.9
7.8
7.8
7.8 4-9
7.9
7.8
5-1030
5-10
5-1030
5-1015