

Lead & Copper Rule Corrosion Control

| Day | pH | Alk | Phos | Other | Y/N |
|-----|------|-----|------|-------|-----|
| 1 | 7.14 | 80 | N/A | | Y |
| 2 | 7.17 | 75 | | | Y |
| 3 | 7.13 | 75 | | | Y |
| 4 | 7.13 | 75 | | | Y |
| 5 | 7.16 | 75 | | | Y |
| 6 | 7.21 | 81 | | | Y |
| 7 | 7.23 | 75 | | | Y |
| 8 | 7.16 | 75 | | | Y |
| 9 | 7.19 | 75 | | | Y |
| 10 | 7.13 | 78 | | | Y |
| 11 | 7.14 | 75 | | | Y |
| 12 | 7.14 | 75 | | | Y |
| 13 | 7.13 | 74 | | | Y |
| 14 | 7.14 | 75 | | | Y |
| 15 | 7.17 | 76 | | | Y |
| 16 | 7.15 | 80 | | | Y |
| 17 | 7.16 | 78 | | | Y |
| 18 | 7.17 | 76 | | | Y |
| 19 | 7.13 | 78 | | | Y |
| 20 | 7.14 | 78 | | | Y |
| 21 | 7.14 | 78 | | | Y |
| 22 | 7.15 | 80 | | | Y |
| 23 | 7.18 | 78 | | | Y |
| 24 | 7.19 | 76 | | | Y |
| 25 | 7.18 | 78 | | | Y |
| 26 | 7.2 | 76 | | | Y |
| 27 | 7.2 | 76 | | | Y |
| 28 | 7.13 | 80 | | | Y |
| 29 | 7.28 | 79 | | | Y |
| 30 | 7.14 | 80 | | | Y |
| 31 | 7.13 | 80 | | | Y |
| | | | | | N |

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

| | | | | |
|---|---|---|---|---|
| 0 | 0 | 3 | 2 | 9 |
|---|---|---|---|---|

System Name: Nesika Beach-Ophir WD

Entry Point: Pump House before Dist.

Sample Period: March 2026

Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

| | | | |
|-------|---|-----|------------------|
| pH | <table border="1"><tr><td>7.1</td></tr></table> | 7.1 | |
| 7.1 | | | |
| Alk | <table border="1"><tr><td>73</td></tr></table> | 73 | (Alkalinity) |
| 73 | | | |
| PO4 | <table border="1"><tr><td>n/a</td></tr></table> | n/a | (Orthophosphate) |
| n/a | | | |
| Other | <table border="1"><tr><td></td></tr></table> | | (_____) |
| | | | |

Print Name: Melvin Trover

Signature: 

Date: 04/06/2026

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's