

ID #	Sample Location	pH	Alk	PO4	Other	Y/N
1/2		7.1	98			Y
1/3		7.3	92			Y
1/4		7.1	90			Y
1/5		7.1	96			Y
1/6		7.1	101			Y
1/7		7.1	97			Y
1/9		7.2	98			Y
1/10		7.1	104			Y
1/11		7.1	93			Y
1/12		7.1	95			Y
1/13		7.1	99			Y
1/14		7.1	105			Y
1/17		7.1	104			Y
1/18		7.1	96			Y
1/19		7.2	88			Y
1/20		7.2	100			Y
1/21		7.2	97			Y
1/23		7.2	96			Y
1/24		7.2	92			Y
1/25		7.2	89			Y
1/26		7.1	93			Y
1/27		7.2	92			Y
1/28		7.2	94			Y
1/31		7.2	96			Y

<Has sample met the minimum(s)?

County: Curry Agency: REGION 2

DISTRIBUTION

PWS ID 4100329

NESIKA BEACH-OPHIR WD

Sample Period: JAN. 2023
Month/Year

Sample Frequency: Every 12 months

Distribution Samples required: 2

Number of excursions during this Sample Period =

(Number of locations when any WQP was less than the minimum.)

Note: Entry Point and Distribution Excursions are cumulative. Add Entry Point and Distribution Excursions to get total for sample period.

Reference

Minimum Water Quality Parameters as set by State:

pH

Alk (Alkalinity)

(N = No = Excursion) Total N's

Print Name: Eric Sheerer

Signature: Eric Sheerer

Date: FEBRUARY 3, 2023

Send to Drinking Water Program within 10 days after end of sampling period:
 OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
 Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>

NBOWD

Date June 30

Soda Ash Per Water Added

	Gallons remaining	Gallons added	Gallons used	Soda ash added	PH	Initials	Comments
1							
2	40	10	10	6	7.1		
3	40	10	10	6	7.2		
4	40	10	10	4	7.1		
5	35	15	15	9	7.1	ED	
6	33	17	17	10	7.1	ED	
7	37	13	13	8	7.1	ED	
8	35	15	15	9	7.1		
9	27	23	23	13	7.2	ED	
10	34	6	6	4	7.1	ZH	85/90 BLEW DIAPHRAGM
11	41	9	9	5	7.1	ED	
12	43	7	7	4	7.1	ED	
13	40	10	10	6	7.1	ED	
14	40	10	10	6	7.1	ED	
15	40	10	10	6	7.14		
16	40	10	22 10	6	7.14		
17	48	5 5	21 10	6	7.1		
18	40	10	10	6	7.1		
19	43	10 7	7	4	7.2		
20	41	9	9	6	7.2	ED	
21	43	7	7	4	7.2	ED	
22	43	7	7	4	7.2		
23	40	10	10	6	7.2		
24	40	10	10	6	7.2		
25	38	12	12	7	7.2	ED	
26	45	5	5	3	7.1	ED	
27	47	3	3	2	7.2	ED	
28	43	7	7	4	7.2	ED	
29	46	0	0	0	7.2		
30	37	13	13	8	7.2		
31	37	13	13	8	7.2		

NBOWD

Date January 23

Chlorine Per Water Added

	Gallons remaining	Gallons added	Gallons used	Chlorine added	pH	Initials	Comments
1							
2	43	6	7	1.3	.64		
3	43	6	7	1.3	.60		
4	45	4	5	1	.61		
5	43	7	7	0	0.82	ZD	
6	42	6	7	1	0.67	ZD	
7	44	6	6	0	0.79	ZD	
8	44	6	6	1.2	0.78		
9	40	0	5	0	.76	ES	40/40
10	35	13	15	2	0.57	ZD	
11	43	7	7	0	0.70	ZD	
12	44	5	6	1	0.63	ZD	
13	44	5	6	1	0.60	ZD	
14	44	5	6	1	0.60	ZD	
15	45	4	5	1	.73		
16	45	4	5	1	.76		
17	45	4	5	1	.64		
18	45	4	5	1	.61		
19			5	1	.54		
20	44	5	6	1	0.53	ZD	
21	45	5	5	0	0.66	ZD	
22	45	5	5	1	.67		
23	43	6	7	1	.50		
24	43	6	7	1	0.70	ZD	
25	43	6	7	1	0.58	ZD	
26	44	5	6	1	0.57	ZD	
27	46	3.5	4	0.5	0.56	ZD	
28	45	5	5	0	0.82	ZD	
29	45	0	0	0	.72		
30	48	48	10	2	.68		
31	45	4	5	1	.79		