

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

ID#	Sample Location	рН	Alk	PO4	other	Y/N	<has sample<="" th=""></has>
	500 SE Butler Rd	7.92					met the DISTRIBUTION minimums?
	700 SE Francis Ave	7.98					
	4800 SE Welch Rd	7.91					PWS ID: 41 00357
	1000 SE Larch Ln	7.97					System Name:City of Gresham
	1400 NE Hacienda Ct	8.17					Sample Period: <u>January 2022</u> Month/Year
	1200 NE 25th St	8.05					Sample Frequency:Every 6 months
	500 NE Hood Ave	7.90			÷.		Distribution Samples required: 10
	1700 NW 13th St	8.19					
	1500 SW Lillyben Ave	7.87					Number of excursions during this Sample Period = <u>\Q</u>
	2600 SW Linneman Dr	7.74					
							(Number of locations when any WQP was less than the minimum.)
							was loss than the miniman.
							Note: Entry Point and Distribution
							Excursions are cumulative. Add Entry Point and Distribution Excursions to get
							total for sample period.
							For OHA use only
-							Tor Grin use only
							Minimum Water Quality
							Parameters as set by
							pH <u>7.5</u>
							Print Name: Lugar Hunter
	(N = No = Excursion) Total N's						Signature: (1-10-22
							Date:

Send to Drinking Water Program within 10 days after end of sampling period: OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405 Website: http://healthoregon.org/dwp/