

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

ID#	Sample Location	рН	Alk	PO4	other	Y/N	<has sample<="" th=""></has>	
	500 SE Butler Rd	8.20					met the minimums?	
	700 SE Francis Ave	8.26						
	4800 SE Welch Rd	8.48					PWS ID: 41 00357	
	1000 SE Larch Ln	8.43					System Name: City of Gresham	
	1400 NE Hacienda Ct	8.48					Sample Period: May 2024 Month/Year	
	1200 NE 25th St	8.59					Sample Frequency:Every 6 months	
	500 NE Hood Ave	853	1				Distribution Samples required: 10	
	1700 NW 13th St	8.56						
	1500 SW Lillyben Ave	8.43	•				Number of excursions during this	
	2600 SW Linneman Dr	8.76					Sample Period =	
							(Number of locations when any WQP was less than the minimum.)	
							Mater Fator Daint and Distribution	
							Note: Entry Point and Distribution Excursions are cumulative. Add Entry	
							Point and Distribution Excursions to get	
							total for sample period.	
							For OUA was only	
							For OHA use only	
							Minimum Water Quality	
							Parameters as set by	
							pH 7.5	
							Print Name: Ky Donahoo	
(N = No = Excursion) Total N's Signa							Signature: Date: 5-7-2024	
	Date: 5-1-2824							
Send to Drinking Water Program within 10 days after end of sampling period:								

Send to Drinking Water Program within 10 days after end of sampling period: OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405 Website: http://healthoregon.org/dwp/