Oregon Health Authority

Water Quality Parameter Monitoring Form

# Lead & Copper Rule Corrosion Control

| ID # | Sample Location | pH | Alk | PO4 | other | Y/N |
|---|---|---|---|---|---|---|
| 1 | 500 SE Butler Rd | 8.18 | | | | |
| 2 | 700 SE Francis Ave | 7.62 | | | | |
| 3 | 4800 SE Welch Rd | 7.74 | | | | |
| 4 | 1000 SE Larch Ln | 7.87 | | | | |
| 5 | 1400 NE Hacienda Ct | 7.98 | | | | |
| 6 | 1200 NE 25th St | 8.11 | | | | |
| 7 | 500 NE Hood Ave | 8.59 | | | | |
| 8 | 1700 NW 13th St | 8.51 | | | | |
| 9 | 1500 SW Lillyben Ave | 8.01 | | | | |
| 10 | 2600 SW Linneman Dr | 8.09 | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |

(N = No = Excursion) **Total N's** 0

<Has sample met the minimums?

## DISTRIBUTION

**PWS ID: 41** 00357

**System Name:** City of Gresham

**Sample Period:** November 2025
*Month/Year*

**Sample Frequency:** Every 6 months

**Distribution Samples required: 10**

**Number of excursions during this Sample Period =** Ø

*(Number of locations when any WQP was less than the minimum.)*

*Note: Entry Point and Distribution Excursions are cumulative. Add Entry Point and Distribution Excursions to get total for sample period.*

*For OHA use only*

**Minimum Water Quality Parameters as set by**

pH 7.5

**Print Name:** Ky Donahoo

**Signature:**

**Date:** 11-21-25

Send to Drinking Water Program within 10 days after end of sampling period:
OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone (971) 673-0405 Website: http://healthoregon.org/dwp/