

Water Quality Parameter Monitoring Form

Lead and Copper Rule Corrsion Control

Day	pH	Alk	Phos other	Y/N
1/1/21	7.55			Yes
1/2/21	7.45			Yes
1/3/21	7.41			Yes
1/4/21	7.54			Yes
1/5/21	7.59			Yes
1/6/21	7.54	22		Yes
1/7/21	7.53			Yes
1/8/21	7.3			Yes
1/9/21	7.61			Yes
1/10/21	7.57			Yes
1/11/21	7.55			Yes
1/12/21	7.55			Yes
1/13/21	7.46	22		Yes
1/14/21	7.58			Yes
1/15/21	7.56			Yes
1/16/21	7.55			Yes
1/17/21	7.54			Yes
1/18/21	7.51			Yes
1/19/21	7.47			Yes
1/20/21	7.59	24		Yes
1/21/21	7.71			Yes
1/22/21	7.7			Yes
1/23/21	7.56			Yes
1/24/21	7.52			Yes
1/25/21	7.48			Yes
1/26/21	7.41			Yes
1/27/21	7.37	22		Yes
1/28/21	7.39			Yes
1/29/21	7.47			Yes
1/30/21	7.44			Yes
1/31/21	7.47			Yes

Entry Point

PWSID 4100359

System name Corbett Water District

Entry Point WTP-A Slow Sand Filter plant

Sample Period Jan-21

Number of excursionsn during this month 0
(count the number of days when any WQP was less than minimum required)

Total excursion during the previous 5 months 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are culmulative)

For OHA use only

Minimum Water Quality

Parameters as set by


pH 7

Alk 8 Alkanlinity

PO4 Orthrophosphate

Other

Print Name Thomas Edwards

Signature 

Date 2/8/2021