

Water Quality Parameter Monitoring Form

Lead and Copper Rule Corrsion Control

Day	pH	Alk	Phos other	Y/N
2/1/21	7.4			Yes
2/2/21	7.44			Yes
2/3/21	7.51	22		Yes
2/4/21	7.6			Yes
2/5/21	7.7			Yes
2/6/21	7.7			Yes
2/7/21	7.66			Yes
2/8/21	7.75			Yes
2/9/21	7.88			Yes
2/10/21	7.97	24		Yes
2/11/21	7.8			Yes
2/12/21	7.63			Yes
2/13/21	7.73			Yes
2/14/21	7.72			Yes
2/15/21	7.36			Yes
2/16/21	7.25			Yes
2/17/21	7.38	22		Yes
2/18/21	7.51			Yes
2/19/21	7.46			Yes
2/20/21	7.46			Yes
2/21/21	7.37			Yes
2/22/21	7.38			Yes
2/23/21	7.57			Yes
2/24/21	7.49	106		Yes
2/25/21	7.51			Yes
2/26/21	7.45			Yes
2/27/21	7.5			Yes
2/28/21	7.49			Yes

Entry Point

PWSID 4100359
System name Corbett Water District
Entry Point WTP-A Slow Sand Filter plant
Sample Period Feb-21

Number of excursionsn during this month 0
(count the number of days when any WQP was
less than minimum required)

Total excursion during the previous 5 months 0

(Over 9 excursions in 6 months is a violation.
Entry Point and Distribution excursions are
culmulative

For OHA use only

Minimum Water Quality			
Parameters as set by			
pH	7		
Alk	8	Alkanlinity	
PO4		Orthrophosphate	
Other			

Print Name

Thomas Edwards

Signature

Thomas Edwards

Date

3/8/2021