

Water Quality Parameter Monitoring Form

Lead and Copper Rule Corrsion Control

Day	pH	Alk	Phos other	Y/N
3/1/21	7.47			Yes
3/2/21	7.48			Yes
3/3/21	7.47	26		Yes
3/4/21	7.43			Yes
3/5/21	7.43			Yes
3/6/21	7.43			Yes
3/7/21	7.37			Yes
3/8/21	7.38			Yes
3/9/21	7.34			Yes
3/10/21	7.32	53		Yes
3/11/21	7.29			Yes
3/12/21	7.32			Yes
3/13/21	7.32			Yes
3/14/21	7.29			Yes
3/15/21	7.28			Yes
3/16/21	7.28			Yes
3/17/21	7.35	55		Yes
3/18/21	7.45			Yes
3/19/21	7.41			Yes
3/20/21	7.35			Yes
3/21/21	7.31			Yes
3/22/21	7.31			Yes
3/23/21	7.33			Yes
3/24/21	7.37	23		Yes
3/25/21	7.34			Yes
3/26/21	7.35			Yes
3/27/21	7.36			Yes
3/28/21	7.35			Yes
3/29/21	7.31			
3/30/21	7.32			
3/31/21	7.36	24		

Entry Point

PWSID 4100359  
 System name Corbett Water District  
 Entry Point WTP-A Slow Sand Filter plant  
 Sample Period Mar-21

Number of excursionsn during this month 0  
 (count the number of days when any WQP was  
 less than minimum required)

Total excursion during the previous 5 months 0

(Over 9 excursions in 6 months is a violation.  
 Entry Point and Distribution excursions are  
 culmulative

For OHA use only

Minimum Water Quality			
Parameters as set by			
pH	7		
Alk	8	Alkanlinity	
PO4		Orthrophosphate	
Other			

Print Name Thomas Edwards

Signature 

Date 4/7/2021