Water Quality Parameter Monitoring Form

Lead and Copper Rule Corrsion Control

Day	рН	Alk	Phos other	Y/N	
4/1/21	7.44			Yes	
4/2/21	7.40			Yes	Entry Point
4/3/21	7.42			Yes	Entry Follit
4/4/21	7.44			Yes	
4/5/21	7.42			Yes	
4/6/21	7.31	23		Yes	PWSID 4100359
4/7/21	7.54			Yes	System name Corbett Water District
4/8/21	7.33			Yes	Entry Point WTP-A Slow Sand Filter plant
4/9/21	7.59			Yes	Sample Period Apr-21
4/10/21	7.73			Yes	
4/11/21	7.48			Yes	Number of excursionsn during this month 0
4/12/21	7.64			Yes	(count the number of days when any WQP was
4/13/21	7.51	19		Yes	less than minimum required)
4/14/21	7.58			Yes	
4/15/21	7.48			Yes	
4/16/21	7.40			Yes	Total excursion during the previous 5 months 0
4/17/21	7.34			Yes	
4/18/21	7.37			Yes	(Over 9 excursions in 6 months is a violation.
4/19/21	7.42			Yes	Entry Point and Distribution excursions are
4/20/21	7.42	20		Yes	culmulative
4/21/21	7.23			Yes	
4/22/21	7.21			Yes	
4/23/21	7.23			Yes	For OHA use only
4/24/21	7.31			Yes	Minimum Water Quality
4/25/21	7.32			Yes	Parameters as set by
4/26/21	7.37			Yes	pH 7
4/27/21	7.36	19		Yes	Alk 8 Alkanlinity
4/28/21	7.40			Yes	PO4 Orthrophosphate
4/29/21	7.34				Other
4/30/21	7.16				
					Print Name Thomas Edwards
					Signature Mrmo Wymb
					Date 5/6/2021