

Water Quality Parameter Monitoring Form

Lead and Copper Rule Corrsion Control

Day	pH	Alk	Phos other	Y/N
5/1/21	7.16			Yes
5/2/21	7.61			Yes
5/3/21	7.60			Yes
5/4/21	7.39			Yes
5/5/21	7.30	65		Yes
5/6/21	7.35			Yes
5/7/21	7.55			Yes
5/8/21	7.59			Yes
5/9/21	7.60			Yes
5/10/21	8.00			Yes
5/11/21	7.76			Yes
5/12/21	7.24	23		Yes
5/13/21	7.04			Yes
5/14/21	7.02			Yes
5/15/21	7.11			Yes
5/16/21	7.05			Yes
5/17/21	7.08			Yes
5/18/21	7.06			Yes
5/19/21	7.21	19		Yes
5/20/21	7.33			Yes
5/21/21	7.64			Yes
5/22/21	7.45			Yes
5/23/21	7.17			Yes
5/24/21	7.15			Yes
5/25/21	7.22			Yes
5/26/21	7.37	4.2		Yes
5/27/21	7.50			Yes
5/28/21	7.73			Yes
5/29/21	7.83			Yes
5/30/21	7.70			Yes
5/31/21	7.63			Yes

Entry Point

PWSID 4100359

System name Corbett Water District

Entry Point WTP-A Slow Sand Filter plant

Sample Period May-21

Number of excursionsn during this month 0
(count the number of days when any WQP was less than minimum required)

Total excursion during the previous 5 months 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are culmulative)

For OHA use only

Minimum Water Quality Parameters as set by


pH 7

Alk 8 Alkanlinity

PO4 Orthrophosphate

Other

Print Name Thomas Edwards

Signature 

Date 6/8/2021