

Water Quality Parameter Monitoring Form

Lead and Copper Rule Corrsion Control

Day	pH	Alk	Phos other	Y/N
6/1/21	7.47			Yes
6/2/21	7.36	11.4		Yes
6/3/21	7.27			Yes
6/4/21	7.22			Yes
6/5/21	7.2			Yes
6/6/21	7.21			Yes
6/7/21	7.27			Yes
6/8/21	7.3			Yes
6/9/21	7.39	8.7		Yes
6/10/21	7.45			Yes
6/11/21	7.44			Yes
6/12/21	7.44			Yes
6/13/21	7.39			Yes
6/14/21	7.37			Yes
6/15/21	7.36			Yes
6/16/21	7.4	10.1		Yes
6/17/21	7.46			Yes
6/18/21	7.45			Yes
6/19/21	7.39			Yes
6/20/21	7.31			Yes
6/21/21	7.22			Yes
6/22/21	7.17			Yes
6/23/21	7.15	16.1		Yes
6/24/21	7.13			Yes
6/25/21	7.11			Yes
6/26/21	7.09			Yes
6/27/21	7.09			Yes
6/28/21	7.12			Yes
6/29/21	7.09			Yes
6/30/21	7.13	17		Yes



Entry Point

PWSID 4100359  
 System name Corbett Water District  
 Entry Point WTP-A Slow Sand Filter plant  
 Sample Period Jun-21

Number of excursionsn during this month 0  
 (count the number of days when any WQP was  
 less than minimum required)

Total excursion during the previous 5 months 0

(Over 9 excursions in 6 months is a violation.  
 Entry Point and Distribution excursions are  
 culmulative

For OHA use only

Minimum Water Quality		
Parameters as set by		
pH	7	
Alk	8	Alkanlinity
PO4		Orthrophosphate
Other		

Print Name David Jacob  
 Signature David Jacob  
 Date 7/7/2021