

Water Quality Parameter Monitoring Form

Lead and Copper Rule Corrsion Control

Day	pH	Alk	Phos other	Y/N
7/1/21	7.2			Yes
7/2/21	7.27			Yes
7/3/21	7.32			Yes
7/4/21	7.31			Yes
7/5/21	7.3			Yes
7/6/21	7.33			Yes
7/7/21	7.29	19		Yes
7/8/21	7.29			Yes
7/9/21	7.33			Yes
7/10/21	7.35			Yes
7/11/21	7.33			Yes
7/12/21	7.31			Yes
7/13/21	7.33			Yes
7/14/21	7.36	20.1		Yes
7/15/21	7.4			Yes
7/16/21	7.44			Yes
7/17/21	7.45			Yes
7/18/21	7.49			Yes
7/19/21	7.49			Yes
7/20/21	7.48			Yes
7/21/21	7.47	20.2		Yes
7/22/21	7.49			Yes
7/23/21	7.53			Yes
7/24/21	7.55			Yes
7/25/21	7.57			Yes
7/26/21	7.56			Yes
7/27/21	7.52			Yes
7/28/21	7.53	24.8		Yes
7/29/21	7.6			Yes
7/30/21	7.55			Yes
7/31/21	7.57			Yes

Entry Point

PWSID 4100359  
 System name Corbett Water District  
 Entry Point WTP-A Slow Sand Filter plant  
 Sample Period Jul-21  
 Number of excursionsn during this month 0  
 (count the number of days when any WQP was less than minimum required)  
 Total excursion during the previous 5 months 0  
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are culmulative)  
 For OHA use only  
 Minimum Water Quality Parameters as set by  
 pH 7  
 Alk 8 Alkanlinity  
 PO4 Orthrophosphate  
 Other

Print Name David Jacob  
 Signature David Jacob  
 Date 8/4/2021