

Water Quality Parameter Monitoring Form

Lead and Copper Rule Corrsion Control

Day	pH	Alk	Phos other	Y/N
9/1/21	7.44	25.9		Yes
9/2/21	7.46			Yes
9/3/21	7.48			Yes
9/4/21	7.49			Yes
9/5/21	7.5			Yes
9/6/21	7.5			Yes
9/7/21	7.49			Yes
9/8/21	7.5	26.9		Yes
9/9/21	7.49			Yes
9/10/21	7.48			Yes
9/11/21	7.48			Yes
9/12/21	7.48			Yes
9/13/21	7.48			Yes
9/14/21	7.48			Yes
9/15/21	7.5	21.5		Yes
9/16/21	7.5			Yes
9/17/21	7.51			Yes
9/18/21	7.52			Yes
9/19/21	7.54			Yes
9/20/21	7.56			Yes
9/21/21	7.59			Yes
9/22/21	7.6			Yes
9/23/21	7.59			Yes
9/24/21	7.58			Yes
9/25/21	7.57			Yes
9/26/21	7.56			Yes
9/27/21	7.53			Yes
9/28/21	7.54			Yes
9/29/21	7.55	34.1		Yes
9/30/21	7.59			Yes

Entry Point

PWSID 4100359
 System name Corbett Water District
 Entry Point WTP-A Slow Sand Filter plant
 Sample Period Sep-21

Number of excursionsn during this month 0
 (count the number of days when any WQP was
 less than minimum required)

Total excursion during the previous 5 months 7
 (Over 9 excursions in 6 months is a violation.
 Entry Point and Distribution excursions are
 culmulative)

For OHA use only

Minimum Water Quality Parameters as set by	pH 7	Alkanlinity 8	Orthrophosphate

Print Name David Jacob
 Signature David Jacob
 Date