

Water Quality Parameter Monitoring Form

Lead and Copper Rule Corrsion Control

Day	pH	Alk	Phos other	Y/N
11/1/21	7.54			Yes
11/2/21	7.57			Yes
11/3/21	7.59	14.2		Yes
11/4/21	7.49			Yes
11/5/21	7.5			Yes
11/6/21	7.56			Yes
11/7/21	7.56			Yes
11/8/21	7.55			Yes
11/9/21	7.4			Yes
11/10/21	7.43	13.2		Yes
11/11/21	7.53			Yes
11/12/21	7.56			Yes
11/13/21	7.69			Yes
11/14/21	7.86			Yes
11/15/21	7.83			Yes
11/16/21	7.83			Yes
11/17/21	7.85	11.8		Yes
11/18/21	7.83			Yes
11/19/21	7.74			Yes
11/20/21	7.93			Yes
11/21/21	7.88			Yes
11/22/21	7.8			Yes
11/23/21	7.69			Yes
11/24/21	7.75	12.4		Yes
11/25/21	7.74			Yes
11/26/21	7.71			Yes
11/27/21	7.63			Yes
11/28/21	7.55			Yes
11/29/21	7.6			Yes
11/30/21	7.53			Yes

Entry Point

PWSID 4100359
 System name Corbett Water District
 Entry Point WTP-A Slow Sand Filter plant
 Sample Period Nov-21

Number of excursionsn during this month 0
 (count the number of days when any WQP was
 less than minimum required)

Total excursion during the previous 5 months 0
 (Over 9 excursions in 6 months is a violation.
 Entry Point and Distribution excursions are
 culmulative)

For OHA use only

Minimum Water Quality Parameters as set by	pH	7	
	Alk	8	Alkanlinity
	PO4		Orthrophosphate
	Other		

Print Name David Jacob
 Signature David Jacob
 Date 12/2/2021