

Water Quality Parameter Monitoring Form

Lead and Copper Rule Corrsion Control

Day	pH	Alk	Phos other	Y/N
12/1/21	7.4	12.4		Yes
12/2/21	7.44			Yes
12/3/21	7.44			Yes
12/4/21	7.43			Yes
12/5/21	7.49			Yes
12/6/21	7.45			Yes
12/7/21	7.42			Yes
12/8/21	7.32	14.8		Yes
12/9/21	7.26			Yes
12/10/21	7.26			Yes
12/11/21	7.46			Yes
12/12/21	7.4			Yes
12/13/21	7.35			Yes
12/14/21	7.35			Yes
12/15/21	7.45	11.7		Yes
12/16/21	7.45			Yes
12/17/21	7.47			Yes
12/18/21	7.48			Yes
12/19/21	7.41			Yes
12/20/21	7.38			Yes
12/21/21	7.45			Yes
12/22/21	7.49	14.3		Yes
12/23/21	7.55			Yes
12/24/21	7.4			Yes
12/25/21	7.39			Yes
12/26/21	7.32			Yes
12/27/21	7.3			Yes
12/28/21	7.31			Yes
12/29/21	7.27	15.4		Yes
12/30/21	7.34			Yes
12/31/21	7.26			Yes

Entry Point

PWSID 4100359
 System name Corbett Water District
 Entry Point WTP-A Slow Sand Filter plant
 Sample Period Dec-21

Number of excursionsn during this month 0
 (count the number of days when any WQP was less than minimum required)

Total excursion during the previous 5 months 0

(Over 9 excursions in 6 months is a violation.
 Entry Point and Distribution excursions are culmulative

For OHA use only

Minimum Water Quality Parameters as set by

pH 7
 Alk 8 Alkanlinity
 PO4 Orthrophosphate
 Other

Print Name David Jacob
 Signature David Jacob
 Date 1/6/2022