

Water Quality Parameter Monitoring Form

Lead and Copper Rule Corrsion Control

Day	pH	Alk	Phos other	Y/N
1/1/22	7.23			Yes
1/2/22	7.21			Yes
1/3/22	7.11			Yes
1/4/22	7.09			Yes
1/5/22	7.09	23.7		Yes
1/6/22	7.14			Yes
1/7/22	7.12			Yes
1/8/22	7.18			Yes
1/9/22	7.31			Yes
1/10/22	7.39			Yes
1/11/22	7.43			Yes
1/12/22	7.42	17.6		Yes
1/13/22	7.38			Yes
1/14/22	7.38			Yes
1/15/22	7.42			Yes
1/16/22	7.34			Yes
1/17/22	7.27			Yes
1/18/22	7.23			Yes
1/19/22	7.19	11		Yes
1/20/22	7.15			Yes
1/21/22	7.15			Yes
1/22/22	7.26			Yes
1/23/22	7.25			Yes
1/24/22	7.22			Yes
1/25/22	7.19			Yes
1/26/22	7.14	20.2		Yes
1/27/22	7.11			Yes
1/28/22	7.04			Yes
1/29/22	7.22			Yes
1/30/22	7.3			Yes
1/31/22	7.24			Yes

Entry Point

PWSID 4100359
 System name Corbett Water District
 Entry Point WTP-A Slow Sand Filter plant
 Sample Period Jan-22

Number of excursionsn during this month 0
 (count the number of days when any WQP was
 less than minimum required)

Total excursion during the previous 5 months 0

(Over 9 excursions in 6 months is a violation.
 Entry Point and Distribution excursions are
 culmulative

For OHA use only

Minimum Water Quality		
Parameters as set by		
pH	7	
Alk	8	Alkanlinity
PO4		Orthrophosphate
Other		

Print Name David Jacob
 Signature David Jacob
 Date 2/4/2022