

Water Quality Parameter Monitoring Form

Lead and Copper Rule Corrsion Control

Day	pH	Alk	Phos other	Y/N
3/1/22	7.55			Yes
3/2/22	7.55	19.3		Yes
3/3/22	7.67			Yes
3/4/22	7.64			Yes
3/5/22	7.55			Yes
3/6/22	7.43			Yes
3/7/22	7.36			Yes
3/8/22	7.35			Yes
3/9/22	7.37	18.2		Yes
3/10/22	7.39			Yes
3/11/22	7.44			Yes
3/12/22	7.49			Yes
3/13/22	7.48			Yes
3/14/22	7.5			Yes
3/15/22	7.5			Yes
3/16/22	7.52	17.2		Yes
3/17/22	7.49			Yes
3/18/22	7.49			Yes
3/19/22	7.51			Yes
3/20/22	7.54			Yes
3/21/22	7.56			Yes
3/22/22	7.58			Yes
3/23/22	7.49	19		Yes
3/24/22	7.45			Yes
3/25/22	7.42			Yes
3/26/22	7.43			Yes
3/27/22	7.37			Yes
3/28/22	7.33			Yes
3/29/22	7.32			Yes
3/30/22	7.32	17.7		Yes
3/31/22	7.34			Yes

Entry Point

PWSID 4100359
 System name Corbett Water District
 Entry Point WTP-A Slow Sand Filter plant
 Sample Period Mar-22
 Number of excursionsn during this month 0
 (count the number of days when any WQP was
 less than minimum required)
 Total excursion during the previous 5 months 0
 (Over 9 excursions in 6 months is a violation.
 Entry Point and Distribution excursions are
 culmulative

For OHA use only

Minimum Water Quality Parameters as set by	pH 7	Alk 8	Alkanlinity
			Orthrophosphate
			Other

Print Name David Jacob
 Signature David Jacob
 Date 4/7/2022