

Water Quality Parameter Monitoring Form

Lead and Copper Rule Corrsion Control

Day	pH	Alk	Phos other	Y/N
4/1/22	7.35			Yes
4/2/22	7.42			Yes
4/3/22	7.42			Yes
4/4/22	7.33			Yes
4/5/22	7.33			Yes
4/6/22	7.34	10		Yes
4/7/22	7.34			Yes
4/8/22	7.26			Yes
4/9/22	7.24			Yes
4/10/22	7.26			Yes
4/11/22	7.23			Yes
4/12/22	7.27			Yes
4/13/22	7.41	13.7		Yes
4/14/22	7.34			Yes
4/15/22	7.29			Yes
4/16/22	7.15			Yes
4/17/22	7.15			Yes
4/18/22	7.11			Yes
4/19/22	7.11			Yes
4/20/22	7.12	9.6		Yes
4/21/22	7.07			Yes
4/22/22	7.05			Yes
4/23/22	7.22			Yes
4/24/22	7.14			Yes
4/25/22	7.09			Yes
4/26/22	7.07			Yes
4/27/22	7.08	11.6		Yes
4/28/22	7.18			Yes
4/29/22	7.27			Yes
4/30/22	7.47			Yes

Entry Point

PWSID 4100359
 System name Corbett Water District
 Entry Point WTP-A Slow Sand Filter plant
 Sample Period Apr-22

Number of excursionsn during this month 0
 (count the number of days when any WQP was less than minimum required)

Total excursion during the previous 5 months
 (Over 9 excursions in 6 months is a violation.
 Entry Point and Distribution excursions are culmulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7
 Alk 8 Alkanlinity
 PO4 Orthrophosphate
 Other

Print Name David Jacob

Signature David Jacob

Date 3-May