

Water Quality Parameter Monitoring Form

Lead and Copper Rule Corrsion Control

Day	pH	Alk	Phos other	Y/N
5/1/22	7.49			Yes
5/2/22	7.36			Yes
5/3/22	7.35			Yes
5/4/22	7.38	16.1		Yes
5/5/22	7.41			Yes
5/6/22	7.6			Yes
5/7/22	7.62			Yes
5/8/22	7.53			Yes
5/9/22	7.46			Yes
5/10/22	7.43			Yes
5/11/22	7.46	12.6		Yes
5/12/22	7.43			Yes
5/13/22	7.43			Yes
5/14/22	7.48			Yes
5/15/22	7.47			Yes
5/16/22	7.4			Yes
5/17/22	7.37			Yes
5/18/22	7.27	12.9		Yes
5/19/22	7.27			Yes
5/20/22	7.3			Yes
5/21/22	7.3			Yes
5/22/22	7.26			Yes
5/23/22	7.2			Yes
5/24/22	7.25			Yes
5/25/22	7.22	11.6		Yes
5/26/22	7.27			Yes
5/27/22	7.23			Yes
5/28/22	7.26			Yes
5/29/22	7.26			Yes
5/30/22	7.28			Yes
5/31/22	7.29			Yes

Entry Point

PWSID 4100359
 System name Corbett Water District
 Entry Point WTP-A Slow Sand Filter plant
 Sample Period May-22

Number of excursionsn during this month 0
 (count the number of days when any WQP was
 less than minimum required)

Total excursion during the previous 5 months 0
 (Over 9 excursions in 6 months is a violation.
 Entry Point and Distribution excursions are
 culmulative)

For OHA use only

Minimum Water Quality Parameters as set by	pH	7	Alkanlinity
	Alk	8	Orthrophosphate
	PO4		
	Other		

Print Name David Jacob
 Signature David Jacob
 Date 6/2/2022