

Water Quality Parameter Monitoring Form

Lead and Copper Rule Corrsion Control

Day	pH	Alk	Phos other	Y/N
6/1/22	7.29	10.3		Yes
6/2/22	7.29			Yes
6/3/22	7.23			Yes
6/4/22	7.24			Yes
6/5/22	7.27			Yes
6/6/22	7.27			Yes
6/7/22	7.27			Yes
6/8/22	7.27	11.1		Yes
6/9/22	7.3			Yes
6/10/22	7.3			Yes
6/11/22	7.33			Yes
6/12/22	7.36			Yes
6/13/22	7.36			Yes
6/14/22	7.36			Yes
6/15/22	7.36	11.1		Yes
6/16/22	7.41			Yes
6/17/22	7.28			Yes
6/18/22	7.21			Yes
6/19/22	7.2			Yes
6/20/22	7.2			Yes
6/21/22	7.23			Yes
6/22/22	7.25	13.1		Yes
6/23/22	7.17			Yes
6/24/22	7.13			Yes
6/25/22	7.13			Yes
6/26/22	7.12			Yes
6/27/22	7.05			Yes
6/28/22	7.05			Yes
6/29/22	7.15	12.4		Yes
6/30/22	7.18			Yes

Entry Point

PWSID 4100359  
 System name Corbett Water District  
 Entry Point WTP-A Slow Sand Filter plant  
 Sample Period Jun-22

Number of excursionsn during this month 0  
 (count the number of days when any WQP was  
 less than minimum required)

Total excursion during the previous 5 months 0  
 (Over 9 excursions in 6 months is a violation.  
 Entry Point and Distribution excursions are  
 culmulative)

For OHA use only

Minimum Water Quality Parameters as set by	pH 7	Alk 8	Alkanlinity
			Orthrophosphate
			Other

Print Name David Jacob  
 Signature David Jacob  
 Date 7/9/2022